


Bay Area WTP

Monthly Operations Report



September, 2019

Water Systems Serial Number: 0465


Ryan Goebel

Water Plant Superintendent

F-1

Title

Classification


Mike Wagar

Operations Supervisor

F-2

Title

Classification

Bay Area Water Treatment Plant

Monthly Operations Report

Supply Name: Bay Area Water System
 WSSN: 0465

Ryan Goebel
 Operator-in-charge

September, 2019
 Month, Year

F-1
 Certification of Operator-in-charge

F-1
 Water Plant Classification

Bay
 County

Treatment Rate and Membrane Data

Treatment Rate, Approved Rated Plant Capacity	17.4	Millions of Gallons per Day
Treatment Rate, Maximum	9.5	Millions of Gallons per Day
Maximum Approved Transmembrane Pressure	22	PSI
Maximum Operating Transmembrane Pressure	22	PSI

Chemical Data

Sodium Hypochlorite on hand:	5,683	Gallons	Estimated Supply:	63.5	days
Caustic Soda on hand:	2,382	Gallons	Estimated Supply:	169.7	days
Corrosion Inhibitor on hand:	1,369	Gallons	Estimated Supply:	55.2	days
Hydrofluosilicic Acid on hand:	1,759	Gallons	Estimated Supply:	82.0	days
Aluminum Chlorohydrate on hand:	1,047	Gallons	Estimated Supply:	54.2	days
Sulfuric Acid on hand:	769	Gallons	Estimated Supply:	216.4	days
Sodium Bisulfite on hand:	749	Gallons	Estimated Supply:	135.9	days
Citric Acid on hand:	2,300	Gallons	Estimated Supply:	235.0	days
Cost of All Chemicals per Million Gallons:	75.67	Dollars			
Estimated Electrical Cost per Million Gallons:	94.25	Dollars			
Estimated Natural Gas Cost per Million Gallons:	0.08	Dollars			

Remarks

Number of periods of filter confluence turbidity samples > 0.3 NTU: 0
 Percent of membrane period confluence samples > 0.3 NTU: 0.00%

Did any individual membrane skid exceed:

1.0 NTU in two consecutive measurements taken 15 minutes apart?
 If yes, attach specific filter(s) information and indicate required follow-up status. No

0.5 NTU in two consecutive measurements taken 15 minutes apart after 4 hours of operation?
 If yes, attach specific filter(s) information and indicate required follow-up status. No

1.0 NTU in two consecutive measurements taken 15 minutes apart for 3 consecutive months?
 If yes, attach specific filter(s) information and indicate required follow-up status. No

2.0 NTU in two consecutive measurements taken 15 minutes apart for 2 consecutive months?
 If yes, attach specific filter(s) information and indicate required follow-up status. No

Was continuous (every 15 minutes) filter monitoring equipment off-line during the month?
 If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet. No

Did POE disinfectant residual fall below 0.2 ppm during the month?
 If yes, indicate date(s) and duration on a separate sheet. No

Was minimum C*T credit achieved for the entire month?
 If no, indicate on a separate sheet the date(s) not achieved. Yes

Was continuous POE chlorine residual monitoring equipment off-line during the month?
 If yes, date(s) and duration will be indicated on the rule page. No

Notes

- Filter #4 was out of service from Sat, Aug 31 @ 4:00pm until Wed, Sept 4 @ 1:00pm for filter feed pressure gauge maintenance
- Only 1 of the 2 required monthly bacteriological samples were collected in Beaver Township (WSSN 0518)
- Only 5 of the 6 required monthly bacteriological samples were collected in Williams Township (WSSN 7125)



Bay Area WTP Monthly Operating Report

Date	Flows									
	Raw Water (MG)			Clarified (MG)	Wasted (MG)	Sludge (MG)	Treated (MG)	Finished Water Pumped (MG)		
	North	South	Total	Total	Total	Total	Total	N. Euclid	Lauria Road	Total
FIT-1000-1	FIT-1000-2	Calculated	FIT-5520-1	FIT-5520-2	FIT-5180	FIT-4000-1	FIT-4040-1	FIT-4040-2	Calculated	
9/1/2019	4.76	4.23	8.99	0.24	0.00	0.09	8.22	4.28	3.81	8.10
9/2/2019	3.77	3.94	7.71	0.31	0.00	0.09	9.45	4.88	4.40	9.28
9/3/2019	4.47	4.45	8.92	0.32	0.00	0.06	8.82	4.56	4.10	8.66
9/4/2019	5.23	4.82	10.05	0.33	0.00	0.06	9.10	4.76	4.29	9.05
9/5/2019	5.08	4.77	9.85	0.34	0.00	0.05	9.46	4.88	4.38	9.26
9/6/2019	4.65	4.46	9.11	0.31	0.00	0.07	8.95	4.62	4.10	8.72
9/7/2019	3.27	3.84	7.11	0.28	0.00	0.07	8.05	4.16	3.73	7.89
9/8/2019	3.73	4.44	8.18	0.28	0.00	0.09	8.21	4.27	3.82	8.08
9/9/2019	3.77	5.50	9.28	0.30	0.00	0.08	8.87	4.65	4.14	8.78
9/10/2019	3.62	5.93	9.55	0.27	0.00	0.08	8.84	4.54	4.04	8.58
9/11/2019	3.40	3.78	7.17	0.26	0.00	0.10	7.41	3.89	3.49	7.38
9/12/2019	3.26	3.27	6.53	0.25	0.00	0.08	7.58	3.82	3.51	7.34
9/13/2019	3.88	4.19	8.08	0.26	0.00	0.08	7.76	3.94	3.60	7.54
9/14/2019	4.11	4.46	8.56	0.26	0.00	0.09	7.76	3.89	3.59	7.48
9/15/2019	3.57	4.21	7.78	0.22	0.00	0.08	7.63	3.87	3.67	7.54
9/16/2019	3.77	4.05	7.82	0.27	0.00	0.08	7.74	3.86	3.64	7.49
9/17/2019	3.88	3.67	7.55	0.27	0.00	0.09	8.23	4.06	3.80	7.86
9/18/2019	3.86	4.74	8.60	0.29	0.00	0.09	8.15	4.10	3.86	7.95
9/19/2019	4.04	4.55	8.59	0.31	0.00	0.08	8.15	4.10	3.84	7.93
9/20/2019	4.07	4.40	8.47	0.22	0.00	0.16	8.24	4.11	3.84	7.96
9/21/2019	3.99	4.22	8.21	0.19	0.00	0.15	7.76	3.85	3.65	7.50
9/22/2019	3.01	4.11	7.12	0.11	0.00	0.23	7.19	3.59	3.40	6.99
9/23/2019	3.36	4.58	7.94	0.13	0.00	0.21	7.79	3.91	3.66	7.57
9/24/2019	3.15	3.84	6.99	0.17	0.00	0.19	7.05	3.56	3.33	6.89
9/25/2019	3.12	3.53	6.65	0.21	0.00	0.13	7.86	3.87	3.65	7.52
9/26/2019	3.82	4.00	7.81	0.28	0.00	0.08	7.54	3.77	3.55	7.31
9/27/2019	4.25	4.11	8.36	0.24	0.00	0.07	7.40	3.71	3.44	7.15
9/28/2019	3.20	3.72	6.92	0.22	0.00	0.09	6.86	3.41	3.21	6.63
9/29/2019	2.76	3.71	6.47	0.25	0.00	0.06	6.84	3.39	3.22	6.61
9/30/2019	3.41	3.82	7.23	0.29	0.00	0.03	7.13	3.50	3.34	6.84
Total	114.25	127.33	241.58	7.70	0.00	2.93	240.07	121.80	112.09	233.88
Avg	3.81	4.24	8.05	0.26	0.00	0.10	8.00	4.06	3.74	7.80
Min	2.76	3.27	6.47	0.11	0.00	0.03	6.84	3.39	3.21	6.61
Max	5.23	5.93	10.05	0.34	0.00	0.23	9.46	4.88	4.40	9.28



Raw Water Analysis								
Date	Temp	pH	Turbidity		F	Free Cl	Bacti	
	Average	Average	Average	Maximum	Grab	Average	Positive/Negative	
	°C		NTU		mg/L	mg/L	Total Coliform	E. coli
	TIT-1000	AIT-1000-2	AIT-1000-1		Lab	AIT-1035-2	Lab	
9/1/2019	17.40	7.76	0.80	18.78	0.06	0.85	Negative	Negative
9/2/2019	17.00	7.77	0.60	3.78	0.08	0.82	Negative	Negative
9/3/2019	16.50	7.77	0.57	1.69	0.08	0.84	Negative	Negative
9/4/2019	15.91	7.79	0.56	1.28	0.08	0.80	Negative	Negative
9/5/2019	15.47	7.81	0.60	1.45	0.06	0.73	Negative	Negative
9/6/2019	15.30	7.88	0.62	0.98	0.08	0.62	Negative	Negative
9/7/2019	15.06	7.85	0.65	3.23	0.08	0.66	Negative	Negative
9/8/2019	14.73	7.95	0.84	1.78	0.08	0.49	Negative	Negative
9/9/2019	15.20	8.05	0.77	1.50	0.06	0.32	Negative	Negative
9/10/2019	16.42	8.13	0.98	1.41	0.09	0.27	Negative	Negative
9/11/2019	16.99	8.09	0.96	2.49	0.07	0.33	Negative	Negative
9/12/2019	17.15	8.13	1.04	1.75	0.09	0.19	Negative	Negative
9/13/2019	17.33	8.12	1.73	7.09	0.11	0.17	Negative	Negative
9/14/2019	17.48	8.03	3.52	11.23	0.08	0.22	Negative	Negative
9/15/2019	17.60	7.99	1.41	6.29	0.11	0.50	Negative	Negative
9/16/2019	17.70	7.96	0.92	3.56	0.11	0.54	Negative	Negative
9/17/2019	17.76	7.97	1.14	3.51	0.11	0.38	Negative	Negative
9/18/2019	17.84	8.00	0.88	2.72	0.11	0.33	Negative	Negative
9/19/2019	17.91	8.04	1.12	1.81	0.10	0.23	Negative	Negative
9/20/2019	18.01	8.10	1.90	4.02	0.10	0.07	Negative	Negative
9/21/2019	18.12	8.09	1.88	3.23	0.10	0.14	Negative	Negative
9/22/2019	18.23	8.12	1.81	2.21	0.10	0.16	Negative	Negative
9/23/2019	18.27	8.02	1.60	3.06	0.10	0.16	Negative	Negative
9/24/2019	17.94	7.82	1.04	1.88	0.10	0.45	Negative	Negative
9/25/2019	17.26	7.78	1.19	10.54	0.09	0.58	Negative	Negative
9/26/2019	16.22	7.75	0.62	2.95	0.09	0.75	Negative	Negative
9/27/2019	15.27	7.74	0.58	1.74	0.09	0.78	Negative	Negative
9/28/2019	14.80	7.73	0.51	1.00	0.09	0.78	Negative	Negative
9/29/2019	14.20	7.72	0.47	1.37	0.09	0.70	Negative	Negative
9/30/2019	13.97	7.77	0.57	1.96	0.09	0.62	Negative	Negative
Avg	16.6	7.92	1.06	3.68	0.09	0.48	NA	NA
Min	14.0	7.72	0.47	0.98	0.06	0.07	NA	NA
Max	18.3	8.13	3.52	18.78	0.11	0.85	NA	NA



Finished Water Analysis																				
Date	Temp	pH	Phosphate	Fluoride		Free Cl ₂	Alkalinity (as CaCO ₃)		Chloride	Sulfate	Calcium (as CaCO ₃)	Dissolved Oxygen	Conductivity	Langelier Saturation Index	Chloride: Sulfate Mass Ratio	Larson-Skold Index	Bacti			
	Average	Average	Average	Tap	Dist	Average	Carbonate	Bicarbonate	Grab	Grab	Grab	Grab	Grab				Positive/Negative			
	°C		mg/L	mg/L		mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	uS/cm				Calculated	Lab	Total Coliform	E. coli
	AIT-4040-1	AIT-4050-2	AIT-4040-5	Lab		AIT-4050-1	Lab		Lab	Lab	Lab	Lab	Lab						Lab	
9/1/2019	15.9	7.32	3.39	0.75		1.24	0	74	11	12	76	10.2	218	-0.98	0.88	0.45	Negative	Negative		
9/2/2019	14.8	7.31	3.38	0.77		1.22	0	74	10	12	74	10.4	217	-1.02	0.83	0.44	Negative	Negative		
9/3/2019	14.2	7.32	3.38	0.76	0.78	1.21	0	79	10	11	72	9.9	216	-1.02	0.94	0.40	Negative	Negative		
9/4/2019	13.3	7.32	3.38	0.75		1.23	0	82	11	13	74	10.0	218	-1.01	0.81	0.42	Negative	Negative		
9/5/2019	12.7	7.31	3.38	0.73		1.22	0	78	10	13	66	10.6	216	-1.10	0.77	0.44	Negative	Negative		
9/6/2019	12.4	7.31	3.38	0.71		1.19	0	77	10	12	70	10.7	220	-1.09	0.83	0.42	Negative	Negative		
9/7/2019	12.3	7.33	3.38	0.75		1.22	0	77	10	13	68	10.3	222	-1.08	0.77	0.44	Negative	Negative		
9/8/2019	12.0	7.34	3.37	0.75		1.21	0	80	10	13	72	10.7	220	-1.05	0.77	0.42	Negative	Negative		
9/9/2019	12.3	7.36	3.37	0.67	0.69	1.20	0	77	11	12	84	10.0	224	-0.97	0.92	0.45	Negative	Negative		
9/10/2019	14.0	7.38	3.37	0.79		1.20	0	75	12	12	82	9.9	228	-0.93	0.98	0.48	Negative	Negative		
9/11/2019	15.6	7.40	3.37	0.79		1.19	0	78	12	10	86	9.4	233	-0.84	1.20	0.43	Negative	Negative		
9/12/2019	16.2	7.42	3.37	0.86		1.20	0	77	12	11	82	8.7	234	-0.83	1.11	0.46	Negative	Negative		
9/13/2019	16.6	7.42	3.37	0.81		1.20	0	78	13	11	82	9.1	235	-0.81	1.16	0.47	Negative	Negative		
9/14/2019	16.9	7.42	3.37	0.79		1.21	0	78	12	11	84	8.7	233	-0.79	1.09	0.45	Negative	Negative		
9/15/2019	17.1	7.39	3.37	0.80		1.22	0	77	12	11	88	8.8	229	-0.80	1.05	0.44	Negative	Negative		
9/16/2019	17.3	7.36	3.41	0.81	0.85	1.21	0	75	12	10	86	8.8	227	-0.85	1.20	0.45	Negative	Negative		
9/17/2019	17.4	7.35	3.38	0.82		1.21	0	78	11	12	78	8.9	224	-0.88	0.92	0.44	Negative	Negative		
9/18/2019	17.5	7.35	3.36	0.80		1.21	0	78	10	13	76	8.7	225	-0.90	0.77	0.44	Negative	Negative		
9/19/2019	17.6	7.36	3.36	0.74		1.20	0	77	11	12	76	8.3	227	-0.89	0.92	0.45	Negative	Negative		
9/20/2019	17.7	7.37	3.36	0.74		1.21	0	77	11	12	72	8.7	236	-0.90	0.92	0.45	Negative	Negative		
9/21/2019	17.8	7.39	3.36	0.74		1.19	0	77	12	13	74	8.3	244	-0.87	0.92	0.49	Negative	Negative		
9/22/2019	17.9	7.41	3.36	0.75		1.20	0	78	11	13	74	8.6	245	-0.84	0.85	0.46	Negative	Negative		
9/23/2019	17.9	7.42	3.36	0.75	0.72	1.20	0	80	11	13	72	8.6	247	-0.83	0.85	0.45	Negative	Negative		
9/24/2019	17.6	7.39	3.36	0.74		1.21	0	70	12	13	76	8.4	242	-0.90	0.88	0.52	Negative	Negative		
9/25/2019	16.8	7.34	3.36	0.74		1.23	0	79	12	13	74	9.3	235	-0.93	0.88	0.46	Negative	Negative		
9/26/2019	15.3	7.30	3.37	0.75		1.24	0	78	11	11	76	9.7	227	-0.99	0.95	0.41	Negative	Negative		
9/27/2019	13.6	7.27	3.37	0.73		1.24	0	74	11	14	74	10.0	222	-1.10	0.79	0.50	Negative	Negative		
9/28/2019	12.5	7.25	3.37	0.75		1.22	0	72	10	14	72	10.7	222	-1.17	0.71	0.49	Negative	Negative		
9/29/2019	11.7	7.25	3.37	0.77		1.19	0	77	11	12	72	10.6	226	-1.16	0.92	0.45	Negative	Negative		
9/30/2019	11.2	7.25	3.37	0.75	0.73	1.21	0	75	10	10	74	10.7	228	-1.17	1.00	0.40	Negative	Negative		
Avg	15.2	7.35	3.37	0.76	0.75	1.21	0	77	11	12	76	9.5	228	-0.96	0.92	0.45	NA	NA		
Min	11.2	7.25	3.36	0.67	0.69	1.19	0	70	10	10	66	8.3	216	-1.17	0.71	0.40	NA	NA		
Max	17.9	7.42	3.41	0.86	0.85	1.24	0	82	13	14	88	10.7	247	-0.79	1.20	0.52	NA	NA		



Turbidity										
Date	Raw Water		Clarified Water	Membrane Feed Water	Combined Membrane Filtrate					Finished Water
	Avg	Max	Avg	Avg	Avg	Max	# Samples	# > 0.3	% Exceeded	Avg
	NTU									
	AIT-1000-1		AIT-5030-1	AIT-1035-3	AIT-4000-1					Calculated
9/1/2019	0.80	18.78	1.07	0.84	0.019	0.019	96	0	0.0	0.014
9/2/2019	0.60	3.78	1.15	0.67	0.019	0.019	96	0	0.0	0.014
9/3/2019	0.57	1.69	1.04	0.62	0.019	0.020	96	0	0.0	0.014
9/4/2019	0.56	1.28	0.96	0.57	0.019	0.019	96	0	0.0	0.014
9/5/2019	0.60	1.45	1.28	0.64	0.019	0.019	96	0	0.0	0.014
9/6/2019	0.62	0.98	1.15	0.61	0.019	0.019	96	0	0.0	0.014
9/7/2019	0.65	3.23	1.24	0.60	0.019	0.019	96	0	0.0	0.014
9/8/2019	0.84	1.78	1.12	0.66	0.019	0.019	96	0	0.0	0.014
9/9/2019	0.77	1.50	1.64	0.71	0.019	0.019	96	0	0.0	0.014
9/10/2019	0.98	1.41	2.41	0.83	0.019	0.019	96	0	0.0	0.014
9/11/2019	0.96	2.49	3.18	1.01	0.019	0.019	96	0	0.0	0.016
9/12/2019	1.04	1.75	1.54	0.98	0.019	0.019	96	0	0.0	0.014
9/13/2019	1.73	7.09	1.75	1.08	0.019	0.019	96	0	0.0	0.014
9/14/2019	3.52	11.23	1.58	2.45	0.019	0.019	96	0	0.0	0.014
9/15/2019	1.41	6.29	1.13	2.33	0.019	0.019	96	0	0.0	0.014
9/16/2019	0.92	3.56	2.35	1.60	0.019	0.019	96	0	0.0	0.014
9/17/2019	1.14	3.51	2.13	1.34	0.019	0.019	96	0	0.0	0.014
9/18/2019	0.88	2.72	1.99	1.10	0.019	0.019	96	0	0.0	0.014
9/19/2019	1.12	1.81	1.77	1.03	0.019	0.019	96	0	0.0	0.014
9/20/2019	1.90	4.02	2.48	1.46	0.019	0.019	96	0	0.0	0.014
9/21/2019	1.88	3.23	2.21	1.79	0.019	0.019	96	0	0.0	0.014
9/22/2019	1.81	2.21	2.44	1.85	0.019	0.019	96	0	0.0	0.014
9/23/2019	1.60	3.06	3.30	1.90	0.019	0.020	96	0	0.0	0.014
9/24/2019	1.04	1.88	2.31	1.52	0.020	0.021	96	0	0.0	0.014
9/25/2019	1.19	10.54	4.34	1.37	0.020	0.020	96	0	0.0	0.014
9/26/2019	0.62	2.95	1.00	0.93	0.019	0.020	96	0	0.0	0.014
9/27/2019	0.58	1.74	1.24	0.78	0.019	0.019	96	0	0.0	0.014
9/28/2019	0.51	1.00	0.57	0.52	0.019	0.020	96	0	0.0	0.014
9/29/2019	0.47	1.37	0.65	0.45	0.019	0.020	96	0	0.0	0.014
9/30/2019	0.57	1.96	0.75	0.40	0.019	0.019	96	0	0.0	0.014
Avg	1.06	3.68	1.72	1.09	0.019	0.019	96	0	0.0	0.014
Min	0.47	0.98	0.57	0.40	0.019	0.019	96	0	0.0	0.014
Max	3.52	18.78	4.34	2.45	0.020	0.021	96	0	0.0	0.016

Note: % Exceeded are 4 hr compliance periods where 50% of the samples are greater than 0.3 NTU



Membrane Integrity																								
Date	Membrane 1			Membrane 2			Membrane 3			Membrane 4			Membrane 5			Membrane 6			Membrane 7			Membrane 8		
	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail	Air Hold Start Pressure (PSI)	Air Hold Stop Pressure (PSI)	Pass / Fail
9/1/2019	14.7	14.3	PASS	14.3	13.7	PASS	14.3	13.9	PASS	Out of Service			14.5	14.0	PASS	14.4	14.1	PASS	14.6	14.2	PASS	14.4	14.0	PASS
9/2/2019	14.7	14.1	PASS	14.3	13.7	PASS	14.7	14.2	PASS	Back in Service 9/4/19			14.1	13.5	PASS	14.4	14.0	PASS	15.1	14.9	PASS	14.3	13.8	PASS
9/3/2019	14.8	14.3	PASS	14.3	13.8	PASS	14.6	14.1	PASS				14.5	13.9	PASS	14.4	14.1	PASS	14.7	14.4	PASS	14.4	13.9	PASS
9/4/2019	14.7	14.2	PASS	14.3	13.8	PASS	14.4	14.0	PASS	14.6	14.2	PASS	14.4	13.8	PASS	14.4	14.0	PASS	15.1	14.8	PASS	14.3	13.8	PASS
9/5/2019	14.7	14.2	PASS	14.3	13.8	PASS	15.4	15.1	PASS	14.5	14.1	PASS	14.6	14.0	PASS	14.4	14.1	PASS	15.3	15.0	PASS	14.3	13.8	PASS
9/6/2019	15.2	14.9	PASS	14.3	13.8	PASS	14.5	14.0	PASS	14.4	14.0	PASS	14.4	13.8	PASS	14.4	14.0	PASS	14.6	14.2	PASS	14.3	13.7	PASS
9/7/2019	14.6	14.1	PASS	14.3	13.8	PASS	15.2	14.8	PASS	14.6	14.2	PASS	14.5	13.9	PASS	14.4	14.0	PASS	14.7	14.3	PASS	14.3	13.8	PASS
9/8/2019	14.6	14.0	PASS	14.3	13.7	PASS	14.6	14.1	PASS	14.5	14.2	PASS	14.4	13.8	PASS	14.4	14.0	PASS	14.8	14.5	PASS	14.3	13.8	PASS
9/9/2019	14.6	14.0	PASS	14.3	13.8	PASS	14.5	14.1	PASS	14.4	14.1	PASS	14.4	13.8	PASS	14.4	14.0	PASS	14.6	14.2	PASS	14.4	13.8	PASS
9/10/2019	14.5	14.0	PASS	14.3	13.7	PASS	14.5	14.1	PASS	14.4	14.1	PASS	14.5	13.9	PASS	14.3	13.8	PASS	14.6	14.2	PASS	14.3	13.7	PASS
9/11/2019	14.8	14.2	PASS	14.8	14.5	PASS	14.7	14.2	PASS	14.7	14.4	PASS	14.3	13.7	PASS	14.4	14.0	PASS	14.4	14.0	PASS	14.3	13.8	PASS
9/12/2019	14.5	13.9	PASS	14.3	13.8	PASS	14.3	13.8	PASS	14.5	14.2	PASS	14.5	13.9	PASS	14.4	14.1	PASS	14.5	14.1	PASS	14.4	13.9	PASS
9/13/2019	14.7	14.2	PASS	14.2	13.7	PASS	15.3	14.9	PASS	14.5	14.2	PASS	15.5	15.2	PASS	14.4	14.1	PASS	14.8	14.4	PASS	14.4	13.9	PASS
9/14/2019	14.6	14.1	PASS	14.3	13.8	PASS	14.8	14.4	PASS	14.5	14.2	PASS	14.1	13.5	PASS	14.4	14.1	PASS	14.6	14.3	PASS	14.3	13.8	PASS
9/15/2019	14.7	14.2	PASS	14.4	14.0	PASS	14.8	14.4	PASS	14.5	14.2	PASS	15.0	14.5	PASS	14.4	14.1	PASS	14.6	14.3	PASS	14.4	13.8	PASS
9/16/2019	14.7	14.2	PASS	14.3	13.7	PASS	15.5	15.3	PASS	14.5	14.1	PASS	14.4	13.8	PASS	14.4	14.0	PASS	14.6	14.3	PASS	14.3	13.8	PASS
9/17/2019	14.6	14.0	PASS	14.3	13.8	PASS	14.4	13.9	PASS	14.5	14.2	PASS	14.1	13.5	PASS	14.4	14.1	PASS	14.7	14.4	PASS	14.4	13.9	PASS
9/18/2019	14.4	13.9	PASS	14.3	13.8	PASS	14.2	13.8	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.4	14.1	PASS	14.7	14.4	PASS	14.4	13.9	PASS
9/19/2019	14.7	14.2	PASS	14.3	13.7	PASS	14.4	13.9	PASS	14.5	14.2	PASS	14.2	13.7	PASS	14.5	14.2	PASS	14.6	14.3	PASS	14.5	14.1	PASS
9/20/2019	14.4	13.9	PASS	14.3	13.8	PASS	14.6	14.1	PASS	14.5	14.2	PASS	15.1	14.6	PASS	14.4	14.1	PASS	14.5	14.1	PASS	14.4	13.9	PASS
9/21/2019	14.6	14.1	PASS	14.3	13.8	PASS	14.5	14.1	PASS	14.5	14.2	PASS	14.3	13.8	PASS	14.5	14.1	PASS	14.3	13.9	PASS	14.4	13.9	PASS
9/22/2019	14.4	13.9	PASS	14.3	13.7	PASS	14.3	13.8	PASS	14.5	14.2	PASS	14.2	13.6	PASS	14.5	14.2	PASS	14.5	14.2	PASS	14.4	13.9	PASS
9/23/2019	14.4	13.9	PASS	14.3	13.7	PASS	14.6	14.2	PASS	14.4	14.0	PASS	14.2	13.6	PASS	14.5	14.2	PASS	14.5	14.1	PASS	14.4	14.0	PASS
9/24/2019	14.5	13.9	PASS	14.3	13.8	PASS	14.3	13.8	PASS	14.4	14.0	PASS	14.4	13.8	PASS	14.4	14.1	PASS	14.5	14.2	PASS	14.4	13.9	PASS
9/25/2019	15.0	14.6	PASS	14.4	13.9	PASS	14.7	14.3	PASS	14.5	14.2	PASS	14.4	13.8	PASS	14.4	14.1	PASS	14.4	14.0	PASS	14.4	13.8	PASS
9/26/2019	14.5	14.0	PASS	14.3	13.8	PASS	14.5	14.0	PASS	14.4	14.0	PASS	14.3	13.7	PASS	14.4	14.1	PASS	15.3	15.0	PASS	14.4	13.8	PASS
9/27/2019	14.8	14.3	PASS	14.3	13.8	PASS	14.7	14.2	PASS	14.4	14.1	PASS	14.5	13.9	PASS	14.4	14.0	PASS	14.5	14.2	PASS	14.3	13.8	PASS
9/28/2019	14.8	14.3	PASS	14.3	13.8	PASS	14.7	14.3	PASS	14.4	14.1	PASS	14.4	13.8	PASS	14.4	14.1	PASS	14.9	14.6	PASS	14.3	13.8	PASS
9/29/2019	14.7	14.2	PASS	14.4	13.9	PASS	14.6	14.1	PASS	14.4	14.1	PASS	14.4	13.8	PASS	14.4	14.0	PASS	14.8	14.4	PASS	14.4	13.8	PASS
9/30/2019	14.9	14.4	PASS	14.3	13.8	PASS	14.8	14.4	PASS	14.3	14.0	PASS	14.4	13.8	PASS	14.4	14.0	PASS	14.6	14.2	PASS	14.3	13.8	PASS

Integrity test performed every 24-hours



Treatment Chemical Dosages											
Date	Treated Water	Sodium Hypochlorite					Phosphoric Acid		Hydroflourosilicic Acid		
		Raw Water	Membrane Feed Water	Dose pre-FW Tanks	Treated Water	Post FW Tanks	Dose pre-FW Tanks	Post FW Tanks	Raw Water	Dose pre-FW Tanks	Post FW Tanks
	Volume	Free Cl ₂					PO4		F		
	MG	mg/L					mg/L		mg/L		
	FIT-4000-1	AIT-1035-2	AIT-1035-4	Added	AIT-4030-1	AIT-4050-1	Added	AIT-4040-5	Lab	Added	Lab
9/1/2019	8.2	0.85	0.61	0.66	1.33	1.24	3.46	3.39	0.06	0.60	0.75
9/2/2019	9.4	0.82	0.62	0.63	1.32	1.22	3.46	3.38	0.08	0.60	0.77
9/3/2019	8.8	0.84	0.66	0.65	1.32	1.21	3.46	3.38	0.08	0.60	0.76
9/4/2019	9.1	0.80	0.68	0.72	1.33	1.23	3.46	3.38	0.08	0.60	0.75
9/5/2019	9.5	0.73	0.65	0.67	1.30	1.22	3.46	3.38	0.06	0.60	0.73
9/6/2019	9.0	0.62	0.56	0.80	1.29	1.19	3.46	3.38	0.08	0.60	0.71
9/7/2019	8.0	0.66	0.52	0.78	1.32	1.22	3.46	3.38	0.08	0.60	0.75
9/8/2019	8.2	0.49	0.46	0.87	1.30	1.21	3.46	3.37	0.08	0.60	0.75
9/9/2019	8.9	0.32	0.34	1.00	1.30	1.20	3.46	3.37	0.06	0.62	0.67
9/10/2019	8.8	0.27	0.22	1.13	1.34	1.20	3.46	3.37	0.09	0.65	0.79
9/11/2019	7.4	0.33	0.18	1.30	1.37	1.19	3.46	3.37	0.07	0.65	0.79
9/12/2019	7.6	0.19	0.13	1.15	1.38	1.20	3.46	3.37	0.09	0.61	0.86
9/13/2019	7.8	0.17	0.10	1.17	1.38	1.20	3.46	3.37	0.11	0.60	0.81
9/14/2019	7.8	0.22	0.08	1.20	1.42	1.21	3.46	3.37	0.08	0.60	0.79
9/15/2019	7.6	0.50	0.18	1.08	1.42	1.22	3.46	3.37	0.11	0.60	0.80
9/16/2019	7.7	0.54	0.27	1.02	1.39	1.21	3.46	3.41	0.11	0.60	0.81
9/17/2019	8.2	0.38	0.27	1.04	1.36	1.21	3.46	3.38	0.11	0.59	0.82
9/18/2019	8.1	0.33	0.24	1.03	1.36	1.21	3.46	3.36	0.11	0.58	0.80
9/19/2019	8.1	0.23	0.19	1.13	1.37	1.20	3.46	3.36	0.10	0.58	0.74
9/20/2019	8.2	0.07	0.08	1.26	1.39	1.21	3.46	3.36	0.10	0.58	0.74
9/21/2019	7.8	0.14	0.04	1.34	1.41	1.19	3.46	3.36	0.10	0.58	0.74
9/22/2019	7.2	0.16	0.05	1.30	1.44	1.20	3.46	3.36	0.10	0.58	0.75
9/23/2019	7.8	0.16	0.04	1.33	1.43	1.20	3.46	3.36	0.10	0.58	0.75
9/24/2019	7.1	0.45	0.11	1.18	1.43	1.21	3.46	3.36	0.10	0.58	0.74
9/25/2019	7.9	0.58	0.19	1.09	1.41	1.23	3.47	3.36	0.09	0.58	0.74
9/26/2019	7.5	0.75	0.36	0.88	1.37	1.24	3.48	3.37	0.09	0.58	0.75
9/27/2019	7.4	0.78	0.53	0.71	1.33	1.24	3.49	3.37	0.09	0.59	0.73
9/28/2019	6.9	0.78	0.59	0.64	1.31	1.22	3.49	3.37	0.09	0.60	0.75
9/29/2019	6.8	0.70	0.59	0.68	1.30	1.19	3.49	3.37	0.09	0.60	0.77
9/30/2019	7.1	0.62	0.56	0.71	1.31	1.21	3.49	3.37	0.09	0.60	0.75
Avg	8.0	0.48	0.34	0.97	1.36	1.21	3.47	3.37	0.09	0.60	0.76
Min	6.8	0.07	0.04	0.63	1.29	1.19	3.46	3.36	0.06	0.58	0.67
Max	9.5	0.85	0.68	1.34	1.44	1.24	3.49	3.41	0.11	0.65	0.86



Disinfection CT														
Date	Pipeline CT				FW Tank CT						Compliance			
	Whitestone	Travel Time	Residual	CT	FW Tank 1	FW Tank 2	Plant	Contact Time	Free Cl ₂	CT	Total CT	Temp	CT	CT
	Flow	Min	RW	Achieved	Min Level	Min Level	Flow	Min	Min	Achieved	Achieved	Avg	Required	Met
	MGD	Minutes	mg/L	mg-min/L	ft	ft	MGD	Minutes	mg/L	mg-min/L	mg-min/L	°C	mg-min/L	Y/N
Entry	Calculated	AIT-1035-2	Calculated	LIT-4005-1	LIT-4005-2	Calculated	Calculated	Calculated	Calculated	Calculated	Calculated	TIT-1000	Calculated	Calculated
9/1/2019	68.2	1,835	0.85	1568	28.9	23.2	8.1	441	1.18	521.18	2,089.22	17.4	4.00	Y
9/2/2019	61.5	2,035	0.82	1667	29.0	24.0	9.3	392	1.19	465.64	2,132.84	17.0	4.00	Y
9/3/2019	54.9	2,279	0.84	1923	28.9	24.8	8.7	425	1.18	502.47	2,425.91	16.5	4.00	Y
9/4/2019	55.0	2,275	0.80	1826	29.0	23.2	9.0	395	1.21	478.12	2,304.15	15.9	4.00	Y
9/5/2019	54.6	2,293	0.73	1676	29.0	23.3	9.3	387	1.20	462.52	2,138.46	15.5	4.00	Y
9/6/2019	57.7	2,169	0.62	1349	28.9	24.3	8.7	418	1.17	488.69	1,837.65	15.3	4.00	Y
9/7/2019	65.9	1,897	0.66	1257	28.9	23.2	7.9	452	1.19	537.65	1,794.19	15.1	4.00	Y
9/8/2019	66.0	1,896	0.49	920	29.0	25.1	8.1	459	1.18	539.48	1,459.80	14.7	6.00	Y
9/9/2019	61.5	2,035	0.32	661	28.9	23.9	8.8	412	1.17	481.40	1,142.27	15.2	4.00	Y
9/10/2019	56.8	2,202	0.27	590	29.0	24.4	8.6	426	1.17	497.69	1,088.00	16.4	4.00	Y
9/11/2019	55.9	2,237	0.33	745	28.9	23.3	7.4	484	1.15	558.90	1,303.55	17.0	4.00	Y
9/12/2019	49.1	2,547	0.19	479	28.9	23.2	7.3	487	1.19	578.98	1,057.97	17.1	4.00	Y
9/13/2019	47.8	2,619	0.17	455	28.8	23.5	7.5	475	1.07	505.97	960.72	17.3	4.00	Y
9/14/2019	62.3	2,008	0.22	446	28.9	23.9	7.5	484	1.18	571.65	1,018.15	17.5	4.00	Y
9/15/2019	62.3	2,006	0.50	995	29.0	23.1	7.5	473	1.20	569.04	1,563.64	17.6	4.00	Y
9/16/2019	58.3	2,145	0.54	1149	28.8	23.0	7.5	473	1.18	556.21	1,704.77	17.7	4.00	Y
9/17/2019	48.8	2,561	0.38	976	28.9	23.5	7.9	457	1.19	543.77	1,519.29	17.8	4.00	Y
9/18/2019	44.0	2,844	0.33	941	28.9	25.0	8.0	464	1.19	552.30	1,492.83	17.8	4.00	Y
9/19/2019	49.0	2,552	0.23	575	28.9	24.1	7.9	458	1.18	537.80	1,113.22	17.9	4.00	Y
9/20/2019	51.5	2,430	0.07	182	29.0	24.2	8.0	458	1.17	535.14	716.88	18.0	4.00	Y
9/21/2019	65.4	1,912	0.14	274	28.9	25.7	7.5	498	1.15	575.18	848.84	18.1	4.00	Y
9/22/2019	65.5	1,909	0.16	301	28.9	24.7	7.0	525	1.17	613.23	914.64	18.2	4.00	Y
9/23/2019	55.4	2,259	0.16	372	28.8	23.6	7.6	474	1.15	547.86	920.29	18.3	4.00	Y
9/24/2019	47.4	2,642	0.45	1202	28.9	23.0	6.9	516	1.18	606.92	1,808.63	17.9	4.00	Y
9/25/2019	55.6	2,248	0.58	1294	29.0	23.3	7.5	477	1.20	574.35	1,868.57	17.3	4.00	Y
9/26/2019	55.7	2,247	0.75	1693	29.0	23.9	7.3	496	1.22	603.04	2,296.01	16.2	4.00	Y
9/27/2019	48.0	2,604	0.78	2033	29.0	24.7	7.2	515	1.21	622.49	2,655.15	15.3	4.00	Y
9/28/2019	53.6	2,334	0.78	1811	28.9	24.6	6.6	554	1.20	662.57	2,473.19	14.8	6.00	Y
9/29/2019	53.6	2,332	0.70	1629	28.9	25.2	6.6	561	1.18	659.47	2,288.08	14.2	6.00	Y
9/30/2019	51.0	2,454	0.62	1531	28.9	22.8	6.8	518	1.20	623.43	2,154.89	14.0	6.00	Y
Avg	56.1	2,260	0.48	1,084	28.9	23.9	7.8	469	1.18	552.44	1,636.39	16.6	4.27	NA
Min	44.0	1,835	0.07	182	28.8	22.8	6.6	387	1.07	462.52	716.88	14.0	4.00	NA
Max	68.2	2,844	0.85	2,033	29.0	25.7	9.3	561	1.22	662.57	2,655.15	18.3	6.00	NA



Notes:

Pipeline volume factor in SMMWSC to RW tank: 125,090 MG-min/day

Distribution System Monitoring

Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl₂)

WSSN: Date	0072 Akron		0390 Bangor Twp.				0400 Bangor Monitor Dist.			0470 Bay City							0485 Bay County					0517 Beaver Rd	0518 Beaver Twp		2180 Essexville
	1	3	4	5	6	7	9	10	11	12	13	14	15	16	17	18	19	20	22	24	26	29	30	32	
	9/1/2019																								
9/2/2019																									
9/3/2019		0.23	0.59	0.44	1.08				0.68	0.10	0.36	0.74	0.17	0.98	0.43	0.82	0.83	0.80	0.97	0.57					
9/4/2019																								0.95	
9/5/2019																									
9/6/2019																									
9/7/2019																									
9/8/2019																									
9/9/2019									0.82	0.33	0.30	0.42	0.23	1.02	0.60	0.87	0.93	0.87	0.84	0.80			0.21	0.85	
9/10/2019						0.97	1.13																		
9/11/2019																									
9/12/2019	0.24	0.46	0.38						0.63	0.10	0.24	0.59	0.11	0.86	0.46						0.98				
9/13/2019																									
9/14/2019																									
9/15/2019																									
9/16/2019																									
9/17/2019		0.28	0.49	0.35	1.08			1.16																1.03	
9/18/2019									0.66	0.16	0.33	0.35	0.11	0.95	0.48										
9/19/2019																									
9/20/2019																									
9/21/2019																									
9/22/2019																									
9/23/2019									0.40	0.11	0.43	0.49	0.08	0.77	0.43									0.94	
9/24/2019																									
9/25/2019																									
9/26/2019									0.48	0.11	0.30	0.54	0.13	0.96	0.29										
9/27/2019																									
9/28/2019																									
9/29/2019																									
9/30/2019																								0.89	
Average	0.24		0.54					1.09				0.45						0.83		0.98		0.21		0.93	
Min	0.24		0.23					0.97				0.08						0.57		0.98		0.21		0.85	
Max	0.24		1.08					1.16				1.02						0.97		0.98		0.21		1.03	



MONITORING STATION ADDRESSES

- | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"> 1. Sample station at corner of 5758 M-25 & F 3. Bangor Fire Station, 3921 Wheeler 4. BCDWS Admin. Bldg. 3933 Patterson Rd. 5. 7-11, 3543 S. Old Kawkawlin Rd. 6. Admiral Petroleum, 314 S Euclid Ave. 7. Sequin Lumber, 3881 Euclid Ave 9. B's Boutique, 2981 Midland Rd 10. Little Caesars, 3475 E North Union Rd | <ul style="list-style-type: none"> 11. Number 1 Fire Station, 1401 Center Ave 12. Number 2 Fire Station, 1000 Fremont Ave 13. Skizak's Sport Shop, 807 Salzburg Ave 14. Number 4 Fire Station, 212 S. Dean St 15. Number 5 Fire Station, 1209 Smith St 16. Bay City Hall, 301 Washington Ave 17. Skipper Buds Marina, 1809 S Water St 18. Bay Valley Animal Hospital 6015 WS Saginaw Rd | <ul style="list-style-type: none"> 19. Dore's M-84 Party Store, 6183 WS Saginaw Rd 20. Pump Station #13, 6000 WS Saginaw Rd 22. Duce's Char House, 432 N. Tuscola Rd 24. Little Learners Daycare, 1694 Cass Ave. 26. Wieland Contracting, 2443 S Mackinaw Rd 29. Sample Station, 2515 S. 11 Mile Rd 30. Sample Station, 340 W. Beaver Rd 32. Essexville City Hall, 1107 Woodside Ave |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Distribution System Monitoring																								
Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl ₂)																								
WSSN:	2465		2960			3565			3570		4280		4440			5330		5335		5540	7125			7134
Date	Fraser Twp.		Hampton Twp.			Kawkawlin Twp.			Kawkawlin Met.		Merritt Twp.		Monitor Twp.			City Pinconning		Pinconning Twp.		Portsmouth	Williams Twp.			Wisner
	34	35	37	38	39	40	41	42	43	45	46	48	49	52	55	58	59	61	63	65	68	69	70	72
9/1/2019																								
9/2/2019																								
9/3/2019			0.59	0.73	0.53															0.51	0.40	0.65		
9/4/2019																								
9/5/2019	0.73	1.02				1.21	0.70		0.69							0.62		0.88	0.57					
9/6/2019																								
9/7/2019																								
9/8/2019																								
9/9/2019			0.46	1.03	0.65																			
9/10/2019													1.03	0.89	0.70						0.62	0.74	0.31	
9/11/2019																								
9/12/2019								0.99	0.50	0.43						0.68								
9/13/2019																				0.51				0.48
9/14/2019																								
9/15/2019																								
9/16/2019			0.59	0.59	0.43																			
9/17/2019													1.03	0.66	0.61									
9/18/2019																								
9/19/2019																								
9/20/2019																								
9/21/2019																								
9/22/2019																								
9/23/2019			0.29																					
9/24/2019																								
9/25/2019																								
9/26/2019																								
9/27/2019																								
9/28/2019																								
9/29/2019																								
9/30/2019																								
Average	0.88		0.59			0.97			0.60	0.41			0.82			0.65		0.73		0.51		0.54	0.48	
Min	0.73		0.29			0.70			0.50	0.38			0.61			0.62		0.57		0.51		0.31	0.48	
Max	1.02		1.03			1.21			0.69	0.43			1.03			0.68		0.88		0.51		0.74	0.48	



MONITORING STATION ADDRESSES

- 34. Fraser Elevated Tank, 2949 1/2 N. Huron Rd
- 35. Lloyd's Cabinet, 1947 N Huron Rd
- 37. Hampton DPW, 950 Wagner Rd.
- 38. Bay County Golf Course, 584 W Hampton Rd.
- 39. Sewer Lift Station, 902 Nebobish Rd.
- 40. Bay Co. Road Commisison, 2600 E Beaver Rd
- 41. Parish Rd. Elevated Tank, 1770 E. Parish Rd
- 42. Linwood Tile, 205 S Huron Rd

- 43. Kawkawlin Party Store, 105 Grove St
- 45. Kawkawlin Restaurant, 103 S Huron Rd
- 46. John's Bar, 1476 S Tuscola Rd
- 48. Tool Shed Bar, 12 W Munger Rd
- 49. Wilder Rd Party Store, 2951 E Wilder Rd
- 52. Monitor Twp. Elevated Tank, 1611 E. Midland Rd
- 55. Auburn Fertilizer, 4640 S 7 Mile Rd
- 58. Pinconning City Hall, 208 S Manitou St

- 59. Marathon Gas Station, 511 S Mabel St
- 61. Pinconning Meter Pit, 3005 N Huron Rd
- 63. Master Meter Pit, 2865 Pinconning Rd
- 65. Ike's Welding, 50 N Finn Rd
- 68. Williams Township Hall, 1080 W Midland Rd
- 69. Pump Station, 490 W. Salzburg & 9 Mile Rd
- 70. 11 Mile Elevated Tank, 5003 S. 11 Mile Rd
- 72. Lindy's Sales, 9051 M-25

Distribution System Bacteriological								
Water Supplier Bacteriological Analysis Report								
MICHIGAN DEPARTMENT OF PUBLIC HEALTH Bureau of Environmental Health Water Supplier Bacteriological Analysis Report				Name of Water Supply Bay Area Water Treatment Plant				
				September, 2019				
COUNTY	COMMUNITY	WSSN NUMBER	DISTRIBUTION SYSTEM SAMPLES					
			avg free cl2 mg/L	NUMBER REQUIRED	NUMBER COLLECTED	NUMBER POSITIVE	NUMBER REPEAT SAMPLES	
Tuscola	Akron	0072	0.24	1	1	0	0	
BAY	Bangor Township	0390	0.54	10	10	0	0	
BAY	Bangor-Monitor Dist.	0400	1.09	3	3	0	0	
BAY	Bay City	0470	0.45	40	42	0	0	
BAY	Bay County (Frankl./Monitor/Portsm.)	0485	0.83	10	10	0	0	
BAY	Beaver Road Area	0517	0.98	1	1	0	0	
BAY	Beaver Township	0518	0.21	2	1	0	0	
BAY	Essexville	2180	0.93	4	5	0	0	
BAY	Fraser Township	2465	0.88	2	2	0	0	
BAY	Hampton Township	2960	0.59	10	10	0	0	
BAY	Kawkawlin Township	3565	0.97	3	3	0	0	
BAY	Kawkawlin Metro Dist.	3570	0.60	2	2	0	0	
BAY	Merritt Township	4280	0.41	2	2	0	0	
BAY	Monitor Township	4440	0.82	6	6	0	0	
BAY	City of Pinconning	5330	0.65	2	2	0	0	
BAY	Pinconning Township	5335	0.73	2	2	0	0	
BAY	Portsmouth Township	5540	0.51	1	2	0	0	
BAY	Williams Township	7125	0.54	6	5	0	0	
Tuscola	Wisner	7134	0.48	1	1	0	0	
Average Free Cl2 Residual of All Distribution Sites			0.65	mg/L				
1. Total distribution samples			110					
2. Total distribution samples with detectable free cl2 residual			110					
3. Total distribution samples with no detectable free cl2 residual			0					
4. Total distribution samples with no detectable free cl2 residual and HPC was <500			NA					
5. Total distribution samples with no detectable free cl2 residual and HPC was >500			NA					
6. Percent of distribution samples with no detectable free cl2 residual			0.00%					
7. Percent shown line #6 in previous monthly report			0.00%					

