


Bay Area WTP

Monthly Operations Report



June, 2021

Water Systems Serial Number: 0465



Ryan Goebel

Water Plant Superintendent

Title

F-1

Classification



Mike Wagar

Operations Supervisor

Title

F-2

Classification

Bay Area Water Treatment Plant

Monthly Operations Report

Supply Name: Bay Area Water System
 WSSN: 0465

June, 2021
 Month, Year

F-1
 Water Plant Classification

Bay
 County

Ryan Goebel
 Operator-in-charge

F-1
 Certification of Operator-in-charge

Treatment Rate and Membrane Data

Treatment Rate, Approved Rated Plant Capacity	17.4	Millions of Gallons per Day
Treatment Rate, Maximum	11.7	Millions of Gallons per Day
Maximum Approved Transmembrane Pressure	22	PSI
Maximum Operating Transmembrane Pressure	14.70	PSI
Maximum Approved Flux Rate	36.25	gpd/sq.ft.
Maximum Operating Flux Rate	29.85	gpd/sq.ft.

Chemical Data

Sodium Hypochlorite on hand:	6,579	Gallons	Estimated Supply:	81.2	days
Caustic Soda on hand:	2,904	Gallons	Estimated Supply:	367.8	days
Corrosion Inhibitor on hand:	906	Gallons	Estimated Supply:	29.6	days
Hydrofluosilicic Acid on hand:	1,961	Gallons	Estimated Supply:	72.4	days
Aluminum Chlorohydrate on hand:	919	Gallons	Estimated Supply:	57.8	days
Sulfuric Acid on hand:	390	Gallons	Estimated Supply:	134.3	days
Sodium Bisulfite on hand:	712	Gallons	Estimated Supply:	171.4	days
Citric Acid on hand:	881	Gallons	Estimated Supply:	180.3	days
Cost of All Chemicals per Million Gallons:	58.60	Dollars			
Estimated Electrical Cost per Million Gallons:	\$71.15	Dollars			
Estimated Natural Gas Cost per Million Gallons:	\$2.26	Dollars			

Remarks

Number of periods of filter confluence turbidity samples > 0.3 NTU	0
Percent of membrane period confluence samples > 0.3 NTU:	0.00%
Was continuous (every 15 minutes) filter monitoring equipment off-line during the month? If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.	No
Did POE disinfectant residual fall below 0.2 ppm during the month? If yes, indicate date(s) and duration on a separate sheet.	No
Was minimum C*T credit achieved for the entire month? If no, indicate on a separate sheet the date(s) not achieved.	Yes
Was continuous POE chlorine residual monitoring equipment off-line during the month? If yes, date(s) and duration will be indicated on the rule page.	No



Notes

Bay Area WTP Monthly Operating Report

Date	Flows								
	Raw Water (MG)			Clarified (MG)	Sludge (MG)	Treated (MG)	Finished Water Pumped (MG)		
	North	South	Total	Total	Total	Total	N. Euclid	Lauria Road	Total
	FIT-1000-1	FIT-1000-2	Calculated	FIT-5520-1	FIT-5180	FIT-4000-1	FIT-4040-1	FIT-4040-2	Calculated
6/1/2021	3.35	7.22	10.56	0.31	0.08	9.58	4.97	4.47	9.44
6/2/2021	3.37	6.48	9.85	0.33	0.08	9.58	4.95	4.49	9.44
6/3/2021	3.41	6.62	10.03	0.34	0.08	10.69	5.41	4.84	10.25
6/4/2021	4.75	6.95	11.70	0.37	0.08	11.18	5.80	5.17	10.96
6/5/2021	6.29	4.87	11.15	0.36	0.08	11.26	5.85	5.21	11.06
6/6/2021	6.13	4.76	10.88	0.36	0.08	11.63	6.11	5.50	11.61
6/7/2021	5.52	7.38	12.89	0.39	0.08	11.74	5.91	5.45	11.36
6/8/2021	5.25	5.64	10.89	0.38	0.08	10.60	5.38	4.98	10.36
6/9/2021	5.32	5.37	10.68	0.34	0.08	11.34	5.74	5.42	11.16
6/10/2021	5.56	6.20	11.76	0.40	0.08	11.59	5.86	5.54	11.40
6/11/2021	5.66	6.90	12.56	0.37	0.08	11.34	5.77	5.22	11.00
6/12/2021	3.91	4.99	8.90	0.30	0.08	8.99	4.75	4.13	8.87
6/13/2021	4.20	4.53	8.73	0.29	0.09	9.37	4.77	4.38	9.15
6/14/2021	4.66	4.85	9.51	0.29	0.08	8.96	4.69	4.12	8.81
6/15/2021	4.44	4.81	9.25	0.30	0.09	8.80	4.56	3.99	8.54
6/16/2021	2.38	5.26	7.64	0.31	0.06	9.97	5.14	4.54	9.68
6/17/2021	3.77	7.50	11.26	0.37	0.05	10.75	5.58	4.94	10.52
6/18/2021	4.76	6.40	11.16	0.34	0.06	9.57	5.02	4.38	9.40
6/19/2021	3.42	5.04	8.46	0.29	0.04	9.05	4.77	4.13	8.90
6/20/2021	2.23	6.66	8.89	0.33	0.04	9.54	4.97	4.34	9.31
6/21/2021	2.01	7.42	9.43	0.33	0.04	9.13	4.81	4.17	8.97
6/22/2021	3.58	5.31	8.89	0.31	0.04	8.46	4.42	3.88	8.30
6/23/2021	3.51	4.15	7.66	0.32	0.04	8.91	4.40	4.18	8.58
6/24/2021	4.05	5.06	9.11	0.31	0.05	8.35	4.39	3.82	8.21
6/25/2021	3.94	4.89	8.84	0.27	0.04	7.64	3.94	3.45	7.39
6/26/2021	2.66	3.38	6.04	0.27	0.06	7.52	3.77	3.51	7.28
6/27/2021	4.08	4.82	8.90	0.28	0.08	8.41	4.31	3.84	8.14
6/28/2021	4.58	4.86	9.44	0.30	0.09	8.52	4.46	3.86	8.32
6/29/2021	3.94	4.32	8.26	0.29	0.07	8.88	4.63	4.06	8.69
6/30/2021	4.10	4.90	9.00	0.30	0.06	9.24	4.80	4.22	9.02
Total	124.79	167.55	292.34	9.76	2.02	290.59	149.90	134.22	284.12
Avg	4.16	5.59	9.74	0.33	0.07	9.69	5.00	4.47	9.47
Min	2.01	3.38	6.04	0.27	0.04	7.52	3.77	3.45	7.28
Max	6.29	7.50	12.89	0.40	0.09	11.74	6.11	5.54	11.61



Raw Water Analysis								
Date	Temp	pH	Turbidity		F ⁻	Free Cl	Bacti	
	Average	Average	Average	Maximum	Grab	Average	Positive/Negative	
	°C		NTU		mg/L	mg/L	Total Coliform	E. coli
	TIT-1000	AIT-1000-2	AIT-1000-1		Lab	AIT-1035-2	Lab	
6/1/2021	12.3	7.94	0.69	2.30	0.09	0.52	Negative	Negative
6/2/2021	12.3	7.93	0.40	1.19	0.09	0.57	Negative	Negative
6/3/2021	12.3	7.95	0.36	1.18	0.09	0.55	Negative	Negative
6/4/2021	12.3	7.98	0.41	1.58	0.08	0.51	Negative	Negative
6/5/2021	12.4	7.98	0.61	1.06	0.08	0.49	Negative	Negative
6/6/2021	12.5	7.98	0.45	0.93	0.08	0.48	Negative	Negative
6/7/2021	12.7	7.98	0.36	1.35	0.08	0.49	Negative	Negative
6/8/2021	12.8	7.99	0.32	1.07	0.08	0.49	Negative	Negative
6/9/2021	12.8	7.99	0.36	6.24	0.08	0.48	Negative	Negative
6/10/2021	12.8	8.02	0.36	4.55	0.08	0.44	Negative	Negative
6/11/2021	13.6	8.04	0.56	2.21	0.08	0.41	Negative	Negative
6/12/2021	14.6	8.09	0.42	0.64	0.10	0.29	Negative	Negative
6/13/2021	15.4	8.10	0.39	1.67	0.10	0.20	Negative	Negative
6/14/2021	15.9	8.07	0.36	1.96	0.09	0.30	Negative	Negative
6/15/2021	16.0	8.03	0.38	1.11	0.09	0.35	Negative	Negative
6/16/2021	16.1	8.03	0.31	0.76	0.09	0.32	Negative	Negative
6/17/2021	16.4	8.01	0.33	1.05	0.09	0.37	Negative	Negative
6/18/2021	16.7	8.04	0.31	0.51	0.10	0.37	Negative	Negative
6/19/2021	16.6	7.95	0.30	0.41	0.09	0.58	Negative	Negative
6/20/2021	16.7	7.94	0.31	0.57	0.09	0.59	Negative	Negative
6/21/2021	16.8	8.01	0.29	0.50	0.09	0.48	Negative	Negative
6/22/2021	16.7	8.00	0.30	0.95	0.08	0.44	Negative	Negative
6/23/2021	16.6	8.00	0.28	3.40	0.09	0.46	Negative	Negative
6/24/2021	16.5	8.01	0.28	2.36	0.09	0.48	Negative	Negative
6/25/2021	16.1	8.04	0.30	1.63	0.08	0.53	Negative	Negative
6/26/2021	15.8	8.05	0.34	1.92	0.08	0.49	Negative	Negative
6/27/2021	15.7	8.04	0.25	0.90	0.08	0.59	Negative	Negative
6/28/2021	15.4	7.99	0.30	1.15	0.09	0.62	Negative	Negative
6/29/2021	15.2	7.96	0.28	0.58	0.08	0.58	Negative	Negative
6/30/2021	15.1	7.99	0.25	0.34	0.08	0.55	Negative	Negative
Avg	14.8	8.00	0.36	1.54	0.09	0.47	NA	NA
Min	12.3	7.93	0.25	0.34	0.08	0.20	NA	NA
Max	16.8	8.10	0.69	6.24	0.10	0.62	NA	NA



Finished Water Analysis																		
Date	Temp	pH	Phosphate	Fluoride		Free Cl ₂	Alkalinity (as CaCO ₃)		Chloride	Sulfate	Calcium (as CaCO ₃)	Dissolved Oxygen	Conductivity	Langelier Saturation Index	Chloride: Sulfate Mass Ratio	Larson-Skold Index	Bacti	
	Average	Average	Average	Tap	Dist	Average	Carbonate	Bicarbonate	Grab	Grab	Grab	Grab	Grab	Index	Ratio	Index	Positive/Negative	
	°C		mg/L	mg/L		mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	uS/cm				Calculated	Lab
	AIT-4040-1	AIT-4050-2	AIT-4040-5	Lab		AIT-4050-1	Lab		Lab	Lab	Lab	Lab	Lab					
6/1/2021	9.8	7.75	3.40	0.78	0.77	1.09	0	84	11	10	70	10.8	236	-0.69	1.10	0.38	Negative	Negative
6/2/2021	9.6	7.72	3.40	0.78		1.12	0	87	11	10	70	11.0	240	-0.70	1.10	0.37	Negative	Negative
6/3/2021	9.3	7.72	3.39	0.79		1.11	0	79	10	9	72	9.3	221	-0.74	1.11	0.37	Negative	Negative
6/4/2021	9.2	7.72	3.41	0.78		1.11	0	80	10	8	72	11.3	223	-0.74	1.25	0.34	Negative	Negative
6/5/2021	9.1	7.73	3.41	0.77		1.11	0	79	9	8	72	11.3	228	-0.73	1.13	0.33	Negative	Negative
6/6/2021	9.0	7.74	3.41	0.76	0.76	1.10	0	78	10	8	70	11.6	223	-0.74	1.25	0.35	Negative	Negative
6/7/2021	9.2	7.74	3.42	0.75		1.10	0	78	10	7	70	11.0	223	-0.74	1.43	0.34	Negative	Negative
6/8/2021	9.0	7.74	3.41	0.74		1.11	0	78	10	8	70	11.1	222	-0.75	1.25	0.35	Negative	Negative
6/9/2021	8.8	7.74	3.40	0.75		1.11	0	76	9	7	72	11.0	218	-0.74	1.29	0.32	Negative	Negative
6/10/2021	8.7	7.75	3.40	0.75		1.12	0	87	9	9	68	11.1	225	-0.71	1.00	0.31	Negative	Negative
6/11/2021	9.4	7.75	3.41	0.72		1.10	0	85	10	10	78	10.8	232	-0.64	1.00	0.35	Negative	Negative
6/12/2021	11.1	7.76	3.42	0.75		1.09	0	82	11	10	82	10.7	233	-0.58	1.10	0.39	Negative	Negative
6/13/2021	12.7	7.77	3.41	0.76		1.08	0	84	11	12	72	9.9	243	-0.58	0.92	0.41	Negative	Negative
6/14/2021	14.0	7.78	3.41	0.74	0.74	1.14	0	88	12	11	72	9.4	249	-0.53	1.09	0.40	Negative	Negative
6/15/2021	14.4	7.77	3.42	0.75		1.21	0	72	11	11	72	10.1	248	-0.61	1.00	0.46	Negative	Negative
6/16/2021	14.3	7.76	3.41	0.76		1.20	0	81	11	11	78	9.4	247	-0.54	1.00	0.41	Negative	Negative
6/17/2021	14.4	7.75	3.40	0.77		1.20	0	84	12	10	78	9.3	248	-0.53	1.20	0.40	Negative	Negative
6/18/2021	15.0	7.75	3.40	0.78		1.20	0	85	13	10	76	9.0	251	-0.52	1.30	0.42	Negative	Negative
6/19/2021	15.1	7.74	3.40	0.77		1.21	0	86	12	10	76	9.2	244	-0.52	1.20	0.39	Negative	Negative
6/20/2021	14.7	7.71	3.41	0.78		1.23	0	82	11	9	76	9.8	235	-0.58	1.22	0.37	Negative	Negative
6/21/2021	14.6	7.72	3.40	0.76	0.77	1.22	0	81	11	8	74	9.2	234	-0.59	1.38	0.36	Negative	Negative
6/22/2021	14.2	7.73	3.39	0.75		1.20	0	81	10	9	72	9.6	231	-0.60	1.11	0.36	Negative	Negative
6/23/2021	14.1	7.73	3.38	0.77		1.22	0	78	11	10	74	9.8	232	-0.60	1.10	0.41	Negative	Negative
6/24/2021	14.1	7.74	3.40	0.77		1.23	0	84	10	10	70	9.7	229	-0.59	1.00	0.36	Negative	Negative
6/25/2021	13.6	7.74	3.40	0.75		1.23	0	83	10	10	71	11.9	230	-0.60	1.00	0.36	Negative	Negative
6/26/2021	12.9	7.74	3.39	0.74		1.20	0	82	9	10	72	10.4	229	-0.61	0.90	0.35	Negative	Negative
6/27/2021	12.5	7.75	3.39	0.76		1.22	0	80	11	10	64	10.7	228	-0.68	1.10	0.40	Negative	Negative
6/28/2021	11.9	7.75	3.39	0.77	0.77	1.22	0	86	10	10	71	10.7	225	-0.62	1.00	0.35	Negative	Negative
6/29/2021	11.4	7.74	3.38	0.75		1.21	0	82	10	10	68	11.4	225	-0.68	1.00	0.37	Negative	Negative
6/30/2021	10.9	7.74	3.37	0.78		1.22	0	78	10	12	72	11.5	224	-0.69	0.83	0.42	Negative	Negative
Avg	11.9	7.74	3.40	0.76	0.76	1.16	0	82	11	10	72	10.4	232	-0.64	1.11	0.37	NA	NA
Min	8.7	7.71	3.37	0.72	0.74	1.08	0	72	9	7	64	9.0	218	-0.75	0.83	0.31	NA	NA
Max	15.1	7.78	3.42	0.79	0.77	1.23	0	88	13	12	82	11.9	251	-0.52	1.43	0.46	NA	NA



Turbidity										
Date	Raw Water		Clarified Water	Membrane Feed Water	Combined Membrane Filtrate					Finished Water
	Avg	Max	Avg	Avg	Avg	Max	# Samples	# > 0.3	% Exceeded	Avg
	NTU									
	AIT-1000-1		AIT-5030-1	AIT-1035-3	AIT-4000-1					Calculated
6/1/2021	0.69	2.30	1.26	1.02	0.022	0.023	96	0	0.0	0.018
6/2/2021	0.40	1.19	1.21	0.61	0.021	0.021	96	0	0.0	0.018
6/3/2021	0.36	1.18	0.75	0.45	0.021	0.021	96	0	0.0	0.017
6/4/2021	0.41	1.58	0.73	0.43	0.021	0.021	96	0	0.0	0.017
6/5/2021	0.61	1.06	1.05	0.54	0.021	0.021	96	0	0.0	0.017
6/6/2021	0.45	0.93	1.39	0.58	0.021	0.021	96	0	0.0	0.018
6/7/2021	0.36	1.35	1.16	0.42	0.021	0.021	96	0	0.0	0.018
6/8/2021	0.32	1.07	1.06	0.35	0.021	0.021	96	0	0.0	0.017
6/9/2021	0.36	6.24	1.21	0.34	0.021	0.021	96	0	0.0	0.017
6/10/2021	0.36	4.55	1.57	0.31	0.021	0.021	96	0	0.0	0.017
6/11/2021	0.56	2.21	1.33	0.40	0.021	0.021	96	0	0.0	0.018
6/12/2021	0.42	0.64	1.69	0.53	0.021	0.021	96	0	0.0	0.018
6/13/2021	0.39	1.67	1.95	0.50	0.021	0.021	96	0	0.0	0.018
6/14/2021	0.36	1.96	1.50	0.41	0.021	0.021	96	0	0.0	0.018
6/15/2021	0.38	1.11	1.76	0.43	0.021	0.021	96	0	0.0	0.018
6/16/2021	0.31	0.76	1.71	0.38	0.021	0.021	96	0	0.0	0.018
6/17/2021	0.33	1.05	2.32	0.42	0.021	0.021	96	0	0.0	0.018
6/18/2021	0.31	0.51	1.67	0.42	0.021	0.021	96	0	0.0	0.018
6/19/2021	0.30	0.41	1.24	0.36	0.021	0.021	96	0	0.0	0.018
6/20/2021	0.31	0.57	0.99	0.34	0.021	0.021	96	0	0.0	0.018
6/21/2021	0.29	0.50	1.01	0.32	0.021	0.021	96	0	0.0	0.018
6/22/2021	0.30	0.95	1.53	0.32	0.021	0.021	96	0	0.0	0.018
6/23/2021	0.28	3.40	1.26	0.30	0.021	0.021	96	0	0.0	0.018
6/24/2021	0.28	2.36	1.67	0.28	0.021	0.021	96	0	0.0	0.018
6/25/2021	0.30	1.63	1.38	0.30	0.021	0.021	96	0	0.0	0.018
6/26/2021	0.34	1.92	1.48	0.35	0.021	0.021	96	0	0.0	0.018
6/27/2021	0.25	0.90	1.59	0.31	0.021	0.021	96	0	0.0	0.018
6/28/2021	0.30	1.15	1.33	0.31	0.021	0.021	96	0	0.0	0.018
6/29/2021	0.28	0.58	1.31	0.31	0.021	0.021	96	0	0.0	0.018
6/30/2021	0.25	0.34	1.33	0.29	0.021	0.021	96	0	0.0	0.018
Avg	0.36	1.54	1.38	0.41	0.021	0.021	96	0	0.0	0.018
Min	0.25	0.34	0.73	0.28	0.021	0.021	96	0	0.0	0.017
Max	0.69	6.24	2.32	1.02	0.022	0.023	96	0	0.0	0.018

Note: % Exceeded are 4 hr compliance periods where the average of samples are greater than 0.3 NTU



Date	Membrane LRV/Integrity/Max Turbidity																									
	Membrane 1			Membrane 2			Membrane 3			Membrane 4			Membrane 5			Membrane 6			Membrane 7			Membrane 8				
	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity		
	Average		Max	Average		Max	Average		Max	Average		Max	Average		Max	Average		Max	Average		Max	Average		Max		
psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU	psi/min	Pass/Fail	NTU
6/1/2021	4.23	PASS	0.023	4.21	PASS	0.033	4.30	PASS	0.028	4.51	PASS	0.018	4.28	PASS	0.024	4.43	PASS	0.022	4.34	PASS	0.034	4.22	PASS	0.019		
6/2/2021	4.26	PASS	0.019	4.22	PASS	0.030	4.30	PASS	0.027	4.57	PASS	0.020	4.32	PASS	0.020	4.45	PASS	0.019	4.46	PASS	0.029	4.25	PASS	0.019		
6/3/2021	4.30	PASS	0.017	4.22	PASS	0.031	4.31	PASS	0.023	4.54	PASS	0.020	4.28	PASS	0.021	4.41	PASS	0.020	4.46	PASS	0.029	4.34	PASS	0.019		
6/4/2021	4.26	PASS	0.019	4.21	PASS	0.029	4.39	PASS	0.023	4.50	PASS	0.020	4.26	PASS	0.021	4.40	PASS	0.019	4.43	PASS	0.029	4.38	PASS	0.021		
6/5/2021	4.23	PASS	0.019	4.20	PASS	0.030	4.24	PASS	0.018	4.49	PASS	0.018	4.24	PASS	0.020	4.40	PASS	0.019	4.41	PASS	0.029	4.28	PASS	0.019		
6/6/2021	4.24	PASS	0.018	4.21	PASS	0.031	4.26	PASS	0.023	4.46	PASS	0.018	4.23	PASS	0.027	4.39	PASS	0.019	4.42	PASS	0.029	4.26	PASS	0.021		
6/7/2021	4.22	PASS	0.018	4.19	PASS	0.030	4.28	PASS	0.022	4.44	PASS	0.018	4.26	PASS	0.020	4.39	PASS	0.019	4.42	PASS	0.029	4.31	PASS	0.018		
6/8/2021	4.24	PASS	0.018	4.20	PASS	0.029	4.24	PASS	0.018	4.48	PASS	0.018	4.25	PASS	0.021	4.40	PASS	0.019	4.39	PASS	0.029	4.26	PASS	0.021		
6/9/2021	4.32	PASS	0.019	4.19	PASS	0.031	4.24	PASS	0.019	4.46	PASS	0.015	4.24	PASS	0.020	4.41	PASS	0.019	4.40	PASS	0.029	4.25	PASS	0.021		
6/10/2021	4.35	PASS	0.019	4.30	PASS	0.028	4.23	PASS	0.022	4.45	PASS	0.015	4.27	PASS	0.021	4.38	PASS	0.019	4.36	PASS	0.029	4.25	PASS	0.023		
6/11/2021	4.22	PASS	0.019	4.31	PASS	0.029	4.22	PASS	0.018	4.49	PASS	0.015	4.26	PASS	0.020	4.41	PASS	0.019	4.41	PASS	0.029	4.34	PASS	0.022		
6/12/2021	4.23	PASS	0.018	4.24	PASS	0.028	4.25	PASS	0.020	4.46	PASS	0.015	4.23	PASS	0.020	4.36	PASS	0.018	4.37	PASS	0.029	4.22	PASS	0.022		
6/13/2021	4.22	PASS	0.019	4.22	PASS	0.027	4.25	PASS	0.019	4.47	PASS	0.015	4.21	PASS	0.020	4.36	PASS	0.018	4.39	PASS	0.029	4.23	PASS	0.022		
6/14/2021	4.20	PASS	0.019	4.23	PASS	0.053	4.31	PASS	0.019	4.48	PASS	0.015	4.21	PASS	0.019	4.39	PASS	0.018	4.39	PASS	0.029	4.23	PASS	0.022		
6/15/2021	4.22	PASS	0.019	4.24	PASS	0.027	4.33	PASS	0.018	4.50	PASS	0.015	4.25	PASS	0.025	4.38	PASS	0.018	4.41	PASS	0.029	4.24	PASS	0.021		
6/16/2021	4.21	PASS	0.020	4.24	PASS	0.027	4.40	PASS	0.019	4.55	PASS	0.015	4.24	PASS	0.020	4.39	PASS	0.018	4.39	PASS	0.029	4.23	PASS	0.019		
6/17/2021	4.21	PASS	0.019	4.22	PASS	0.027	4.38	PASS	0.018	4.51	PASS	0.015	4.24	PASS	0.021	4.40	PASS	0.018	4.39	PASS	0.029	4.21	PASS	0.022		
6/18/2021	4.20	PASS	0.019	4.22	PASS	0.028	4.31	PASS	0.018	4.50	PASS	0.015	4.23	PASS	0.020	4.39	PASS	0.018	4.41	PASS	0.029	4.24	PASS	0.022		
6/19/2021	4.20	PASS	0.019	4.24	PASS	0.027	4.32	PASS	0.018	4.54	PASS	0.015	4.24	PASS	0.020	4.43	PASS	0.018	4.44	PASS	0.029	4.23	PASS	0.023		
6/20/2021	4.23	PASS	0.019	4.24	PASS	0.027	4.34	PASS	0.018	4.57	PASS	0.015	4.26	PASS	0.019	4.40	PASS	0.018	4.43	PASS	0.029	4.23	PASS	0.019		
6/21/2021	4.25	PASS	0.019	4.24	PASS	0.026	4.35	PASS	0.018	4.56	PASS	0.015	4.26	PASS	0.019	4.46	PASS	0.018	4.48	PASS	0.029	4.27	PASS	0.018		
6/22/2021	4.22	PASS	0.019	4.25	PASS	0.026	4.33	PASS	0.018	4.56	PASS	0.015	4.26	PASS	0.019	4.41	PASS	0.019	4.46	PASS	0.029	4.28	PASS	0.018		
6/23/2021	4.25	PASS	0.019	4.27	PASS	0.027	4.34	PASS	0.018	4.57	PASS	0.015	4.25	PASS	0.021	4.46	PASS	0.018	4.45	PASS	0.029	4.27	PASS	0.022		
6/24/2021	4.22	PASS	0.020	4.26	PASS	0.027	4.34	PASS	0.018	4.58	PASS	0.015	4.28	PASS	0.019	4.50	PASS	0.018	4.47	PASS	0.029	4.26	PASS	0.022		
6/25/2021	4.25	PASS	0.019	4.29	PASS	0.029	4.34	PASS	0.018	4.56	PASS	0.015	4.28	PASS	0.019	4.52	PASS	0.018	4.48	PASS	0.029	4.25	PASS	0.019		
6/26/2021	4.26	PASS	0.019	4.33	PASS	0.027	4.35	PASS	0.018	4.60	PASS	0.015	4.27	PASS	0.020	4.48	PASS	0.018	4.46	PASS	0.029	4.27	PASS	0.019		
6/27/2021	4.24	PASS	0.018	4.29	PASS	0.030	4.36	PASS	0.018	4.61	PASS	0.015	4.26	PASS	0.020	4.47	PASS	0.019	4.45	PASS	0.029	4.23	PASS	0.021		
6/28/2021	4.23	PASS	0.019	4.28	PASS	0.027	4.37	PASS	0.019	4.58	PASS	0.015	4.25	PASS	0.025	4.47	PASS	0.019	4.51	PASS	0.029	4.28	PASS	0.020		
6/29/2021	4.23	PASS	0.019	4.26	PASS	0.028	4.35	PASS	0.018	4.57	PASS	0.015	4.27	PASS	0.019	4.48	PASS	0.018	4.44	PASS	0.028	4.27	PASS	0.019		
6/30/2021	4.26	PASS	0.018	4.26	PASS	0.027	4.35	PASS	0.018	4.60	PASS	0.015	4.27	PASS	0.021	4.45	PASS	0.019	4.43	PASS	0.029	4.25	PASS	0.019		
Avg	4.24		0.019	4.24		0.029	4.31		0.020	4.52		0.016	4.25		0.021	4.42		0.019	4.43		0.029	4.26		0.020		
Min	4.20		0.017	4.19		0.026	4.22		0.018	4.44		0.015	4.21		0.019	4.36		0.018	4.34		0.028	4.21		0.018		
Max	4.35		0.023	4.33		0.053	4.40		0.028	4.61		0.020	4.32		0.027	4.52		0.022	4.51		0.034	4.38		0.023		

*LRV not to exceed Upper Control Limit of 3.32 psi/min



Treatment Chemical Dosages											
Date	Treated Water	Sodium Hypochlorite					Phosphoric Acid		Hydrofluorosilicic Acid		
		Raw Water	Membrane Feed Water	Dose pre-FW Tanks	Treated Water	Post FW Tanks	Dose pre-FW Tanks	Post FW Tanks	Raw Water	Dose pre-FW Tanks	Post FW Tanks
	Volume	Free Cl ₂					PO ₄		F		
	MG	mg/L					mg/L		mg/L		
	FIT-4000-1	AIT-1035-2	AIT-1035-4	Added	AIT-4030-1	AIT-4050-1	Added	AIT-4040-5	Lab	Added	Lab
6/1/2021	9.6	0.52	0.33	0.76	1.21	1.09	3.22	3.40	0.09	0.63	0.78
6/2/2021	9.6	0.57	0.47	0.67	1.20	1.12	3.22	3.40	0.09	0.63	0.78
6/3/2021	10.7	0.55	0.45	0.60	1.19	1.11	3.22	3.39	0.09	0.63	0.79
6/4/2021	11.2	0.51	0.43	0.56	1.20	1.11	3.22	3.41	0.08	0.63	0.78
6/5/2021	11.3	0.49	0.41	0.56	1.19	1.11	3.22	3.41	0.08	0.63	0.77
6/6/2021	11.6	0.48	0.40	0.56	1.19	1.10	3.22	3.41	0.08	0.63	0.76
6/7/2021	11.7	0.49	0.40	0.56	1.19	1.10	3.22	3.42	0.08	0.63	0.75
6/8/2021	10.6	0.49	0.40	0.56	1.20	1.11	3.22	3.41	0.08	0.63	0.74
6/9/2021	11.3	0.48	0.40	0.56	1.19	1.11	3.22	3.40	0.08	0.63	0.75
6/10/2021	11.6	0.44	0.39	0.57	1.20	1.12	3.22	3.40	0.08	0.63	0.75
6/11/2021	11.3	0.41	0.32	0.64	1.19	1.10	3.22	3.41	0.08	0.64	0.72
6/12/2021	9.0	0.29	0.28	0.67	1.20	1.09	3.22	3.42	0.10	0.64	0.75
6/13/2021	9.4	0.20	0.18	0.76	1.21	1.08	3.22	3.41	0.10	0.64	0.76
6/14/2021	9.0	0.30	0.16	0.85	1.31	1.14	3.22	3.41	0.09	0.65	0.74
6/15/2021	8.8	0.35	0.20	0.85	1.36	1.21	3.22	3.42	0.09	0.66	0.75
6/16/2021	10.0	0.32	0.21	0.81	1.32	1.20	3.22	3.41	0.09	0.66	0.76
6/17/2021	10.8	0.37	0.24	0.78	1.32	1.20	3.22	3.40	0.09	0.66	0.77
6/18/2021	9.6	0.37	0.27	0.78	1.33	1.20	3.22	3.40	0.10	0.66	0.78
6/19/2021	9.0	0.58	0.31	0.73	1.34	1.21	3.22	3.40	0.09	0.66	0.77
6/20/2021	9.5	0.59	0.39	0.66	1.34	1.23	3.22	3.41	0.09	0.66	0.78
6/21/2021	9.1	0.48	0.39	0.82	1.32	1.22	3.22	3.40	0.09	0.66	0.76
6/22/2021	8.5	0.44	0.34	0.90	1.31	1.20	3.22	3.39	0.08	0.66	0.75
6/23/2021	8.9	0.46	0.35	0.87	1.33	1.22	3.22	3.38	0.09	0.66	0.77
6/24/2021	8.3	0.48	0.36	0.87	1.33	1.23	3.22	3.40	0.09	0.66	0.77
6/25/2021	7.6	0.53	0.39	0.82	1.32	1.23	3.22	3.40	0.08	0.67	0.75
6/26/2021	7.5	0.49	0.37	0.86	1.32	1.20	3.22	3.39	0.08	0.67	0.74
6/27/2021	8.4	0.59	0.41	0.78	1.32	1.22	3.22	3.39	0.08	0.67	0.76
6/28/2021	8.5	0.62	0.45	0.75	1.32	1.22	3.22	3.39	0.09	0.67	0.77
6/29/2021	8.9	0.58	0.46	0.75	1.30	1.21	3.21	3.38	0.08	0.67	0.75
6/30/2021	9.2	0.55	0.45	0.80	1.31	1.22	3.21	3.37	0.08	0.67	0.78
Avg	9.7	0.47	0.35	0.72	1.27	1.16	3.22	3.40	0.09	0.65	0.76
Min	7.5	0.20	0.16	0.56	1.19	1.08	3.21	3.37	0.08	0.63	0.72
Max	11.7	0.62	0.47	0.90	1.36	1.23	3.22	3.42	0.10	0.67	0.79



Disinfection CT														
Date	Pipeline CT				FW Tank CT						Compliance			
	Whitestone	Travel Time	Residual	CT	FW Tank 1	FW Tank 2	Plant	Contact Time	Free Cl ₂	CT	Total CT	Temp	CT	CT
	Flow	Min	RW	Achieved	Min Level	Min Level	Flow	Min	Min	Achieved	Achieved	Avg	Required	Met
	MGD	Minutes	mg/L	mg-min/L	ft	ft	MGD	Minutes	mg/L	mg-min/L	mg-min/L	°C	mg-min/L	Y/N
Entry	Calculated	AIT-1035-2	Calculated	LIT-4005-1	LIT-4005-2	Calculated	Calculated	Calculated	Calculated	Calculated	TIT-1000	Calculated	Calculated	
6/1/2021	54.6	2,292	0.52	1200	28.7	22.1	9.4	369	1.04	382.65	1,582.26	12.3	6.00	Y
6/2/2021	54.9	2,279	0.57	1296	28.9	19.5	9.4	351	1.06	373.29	1,669.38	12.3	6.00	Y
6/3/2021	55.9	2,237	0.55	1225	29.0	22.1	10.3	341	1.06	363.53	1,588.93	12.3	6.00	Y
6/4/2021	63.5	1,970	0.51	1001	28.9	24.8	11.0	336	1.06	357.60	1,358.68	12.3	6.00	Y
6/5/2021	75.8	1,650	0.49	803	28.9	24.7	11.1	332	1.09	362.27	1,165.06	12.4	6.00	Y
6/6/2021	76.2	1,641	0.48	786	28.9	22.1	11.6	301	1.07	322.62	1,108.83	12.5	6.00	Y
6/7/2021	73.8	1,695	0.49	835	28.8	22.1	11.4	307	1.09	333.59	1,168.22	12.7	6.00	Y
6/8/2021	65.5	1,910	0.49	937	28.8	24.5	10.4	353	1.08	380.31	1,317.39	12.8	6.00	Y
6/9/2021	65.6	1,908	0.48	922	28.8	24.0	11.2	324	1.07	347.40	1,269.15	12.8	6.00	Y
6/10/2021	65.9	1,898	0.44	845	28.8	21.5	11.4	302	1.06	319.56	1,164.16	12.8	6.00	Y
6/11/2021	76.6	1,634	0.41	663	28.8	23.5	11.0	326	1.07	349.18	1,012.16	13.6	6.00	Y
6/12/2021	76.9	1,626	0.29	477	28.8	25.4	8.9	419	1.04	436.99	914.41	14.6	6.00	Y
6/13/2021	63.9	1,959	0.20	398	28.8	23.3	9.2	390	1.02	396.13	794.48	15.4	4.00	Y
6/14/2021	61.8	2,024	0.30	603	28.8	23.5	8.8	406	1.04	424.34	1,027.13	15.9	4.00	Y
6/15/2021	58.5	2,137	0.35	753	28.8	23.0	8.5	416	1.12	465.73	1,218.89	16.0	4.00	Y
6/16/2021	49.8	2,514	0.32	808	28.8	24.6	9.7	378	1.16	438.95	1,246.97	16.1	4.00	Y
6/17/2021	57.7	2,167	0.37	809	28.7	24.4	10.5	346	1.14	394.72	1,203.64	16.4	4.00	Y
6/18/2021	58.1	2,153	0.37	791	28.9	25.5	9.4	396	1.17	462.40	1,253.46	16.7	4.00	Y
6/19/2021	66.5	1,881	0.58	1098	28.7	23.7	8.9	404	1.16	469.26	1,567.15	16.6	4.00	Y
6/20/2021	66.9	1,870	0.59	1103	28.9	24.8	9.3	395	1.18	464.38	1,566.99	16.7	4.00	Y
6/21/2021	64.8	1,930	0.48	936	28.9	24.6	9.0	409	1.14	466.22	1,402.00	16.8	4.00	Y
6/22/2021	55.7	2,244	0.44	996	28.7	24.4	8.3	439	1.16	509.46	1,505.91	16.7	4.00	Y
6/23/2021	49.7	2,517	0.46	1169	28.8	24.7	8.6	427	1.16	495.73	1,664.87	16.6	4.00	Y
6/24/2021	47.3	2,644	0.48	1262	28.7	22.5	8.2	427	1.20	511.16	1,773.17	16.5	4.00	Y
6/25/2021	47.5	2,631	0.53	1393	28.7	23.5	7.4	484	1.18	568.74	1,961.64	16.1	4.00	Y
6/26/2021	51.8	2,416	0.49	1192	28.7	23.3	7.3	490	1.13	555.29	1,747.52	15.8	4.00	Y
6/27/2021	52.9	2,363	0.59	1389	28.7	23.9	8.1	442	1.16	513.61	1,902.71	15.7	4.00	Y
6/28/2021	53.2	2,351	0.62	1449	28.7	24.3	8.3	437	1.19	519.64	1,968.84	15.4	4.00	Y
6/29/2021	49.5	2,528	0.58	1467	28.7	23.9	8.7	415	1.18	487.64	1,954.36	15.2	4.00	Y
6/30/2021	48.0	2,606	0.55	1429	28.7	23.0	9.0	393	1.18	463.99	1,893.04	15.1	4.00	Y
Avg	60.3	2,122	0.47	1,001	28.8	23.6	9.5	385	1.12	431.21	1,432.38	14.8	4.80	NA
Min	47.3	1,626	0.20	398	28.7	19.5	7.3	301	1.02	319.56	794.48	12.3	4.00	NA
Max	76.9	2,644	0.62	1,467	29.0	25.5	11.6	490	1.20	568.74	1,968.84	16.8	6.00	NA



Notes:

Pipeline volume factor in SMMWSC to RW tank: 125,090 MG-min/day

Distribution System Monitoring

Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl₂)

WSSN:	0072	0390				0400			0470							0485					0517	0518		2180
	Akron	Bangor Twp.				Bangor Monitor Dist.			Bay City							Bay County					Beaver Rd	Beaver Twp		Essexville
Date	1	3	4	5	6	7	9	10	11	12	13	14	15	16	17	18	19	20	23	24	26	29	30	32
6/1/2021									0.76	0.43	0.51	0.74	0.44	0.99	0.72									0.85
6/2/2021																								
6/3/2021				0.61	0.97	0.85	0.95		0.73	0.43	0.54	0.80	0.46	1.02	0.78							0.45		
6/4/2021																								
6/5/2021																								
6/6/2021																								
6/7/2021																								0.95
6/8/2021	0.45								0.81	0.32	0.63	0.67	0.36	0.90	0.64	0.78	0.76	0.65	0.82	0.75				
6/9/2021																								
6/10/2021		0.60	0.58	0.65	0.97																	0.64		
6/11/2021																								
6/12/2021																								
6/13/2021																								
6/14/2021																								
6/15/2021									0.79	0.52	0.52	0.70	0.44	0.92	0.66	0.73	0.69	0.82	0.80	0.68	0.73			0.94
6/16/2021																								
6/17/2021		0.55	0.47	0.62	1.05				0.69	0.33	0.44	0.90	0.32	0.89	0.81							0.52		
6/18/2021																								
6/19/2021																								
6/20/2021																								
6/21/2021																								0.94
6/22/2021								1.06																
6/23/2021									0.68	0.21	0.37	0.74	0.24	0.80	0.57									
6/24/2021																								
6/25/2021																								
6/26/2021																								
6/27/2021																								
6/28/2021																								1.08
6/29/2021									0.73	0.32	0.56	0.89	0.32	0.95	0.51									
6/30/2021																								
Average	0.45			0.71				0.95					0.62							0.75		0.73		0.95
Min	0.45			0.47				0.85					0.21							0.65		0.73		0.85
Max	0.45			1.05				1.06					1.02							0.82		0.73		1.08



MONITORING STATION ADDRESSES

- | | | |
|--|---|---|
| 1. Sample station at corner of 5758 M-25 & F | 11. Number 1 Fire Station, 1401 Center Ave | 19. Dore's M-84 Party Store, 6183 WS Saginaw Rd |
| 3. Bangor Fire Station, 3921 Wheeler | 12. Number 2 Fire Station, 1000 Fremont Ave | 20. Pump Station #13, 6000 WS Saginaw Rd |
| 4. BCDWS Admin. Bldg. 3933 Patterson Rd. | 13. Skizak's Sport Shop, 807 Salzburg Ave | 23. Rail Trail Pump Station, 366 N. Tuscola Rd. |
| 5. 7-11, 3543 S. Old Kawkawlin Rd. | 14. Number 4 Fire Station, 212 S. Dean St | 24. Little Learners Daycare, 1694 Cass Ave. |
| 6. Admiral Petroleum, 314 S Euclid Ave. | 15. Number 5 Fire Station, 1209 Smith St | 26. Wieland Contracting, 2443 S Mackinaw Rd |
| 7. Sequin Lumber, 3881 Euclid Ave | 16. Bay City Hall, 301 Washington Ave | 29. Sample Station, 2515 S. 11 Mile Rd |
| 9. B's Boutique, 2981 Midland Rd | 17. Skipper Buds Marina, 1809 S Water St | 30. Sample Station, 340 W. Beaver Rd |
| 10. Little Caesars, 3475 E North Union Rd | 18. Bay Valley Animal Hospital 6015 WS Saginaw Rd | 32. Essexville City Hall, 1107 Woodside Ave |

Distribution System Monitoring																								
Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl2)																								
WSSN:	2465		2960			3565			3570		4280		4440			5330		5335		5540	7125			7134
Date	Fraser Twp.		Hampton Twp.			Kawkawlin Twp.			Kawkawlin Met.		Merritt Twp.		Monitor Twp.			City Pinconning		Pinconning Twp.		Portsmouth	Williams Twp.			Wisner
	34	35	37	38	39	40	41	42	43	45	46	48	49	52	55	58	59	61	63	65	68	69	70	72
6/1/2021																								
6/2/2021																								
6/3/2021													0.97	0.71	0.75						0.52		0.67	
6/4/2021			0.51	0.53	0.56																			
6/5/2021																								
6/6/2021																								
6/7/2021			0.67	0.73	0.72																			
6/8/2021	0.83	0.85				1.01			0.80		0.65					0.34		0.86	0.80	0.73				0.63
6/9/2021																						0.48	0.77	0.63
6/10/2021																								
6/11/2021																								
6/12/2021																								
6/13/2021																								
6/14/2021			0.54	0.69	0.61																			
6/15/2021								0.98	0.81		0.58					0.59								
6/16/2021																								
6/17/2021																					0.65	0.82	0.61	
6/18/2021																								
6/19/2021																								
6/20/2021																								
6/21/2021			0.54	0.81	0.52																			
6/22/2021								0.99					0.98	0.70	0.71									
6/23/2021																								
6/24/2021																								
6/25/2021																								
6/26/2021																								
6/27/2021																								
6/28/2021																								
6/29/2021																								
6/30/2021																								
Average	0.84		0.62			0.99			0.81		0.62		0.80			0.47		0.83		0.73	0.64			0.63
Min	0.83		0.51			0.98			0.80		0.58		0.70			0.34		0.80		0.73	0.48			0.63
Max	0.85		0.81			1.01			0.81		0.65		0.98			0.59		0.86		0.73	0.82			0.63



MONITORING STATION ADDRESSES

- 34. Fraser Elevated Tank, 2949 1/2 N. Huron Rd
- 35. Lloyd's Cabinet, 1947 N Huron Rd
- 37. Hampton DPW, 950 Wagner Rd.
- 38. Bay County Golf Course, 584 W Hampton Rd.
- 39. Sewer Lift Station, 902 Nebobish Rd.
- 40. Bay Co. Road Commisison, 2600 E Beaver Rd
- 41. Parish Rd. Elevated Tank, 1770 E. Parish Rd
- 42. Linwood Tile, 205 S Huron Rd

- 43. Kawkawlin Party Store, 105 Grove St
- 45. Kawkawlin Restaurant, 103 S Huron Rd
- 46. John's Bar, 1476 S Tuscola Rd
- 48. Tool Shed Bar, 12 W Munger Rd
- 49. Wilder Rd Party Store, 2951 E Wilder Rd
- 52. Monitor Twp. Elevated Tank, 1611 E. Midland Rd
- 55. Auburn Fertilizer, 4640 S 7 Mile Rd
- 58. Pinconning City Hall, 208 S Manitou St

- 59. Marathon Gas Station, 511 S Mabel St
- 61. Pinconning Meter Pit, 3005 N Huron Rd
- 63. Master Meter Pit, 2865 Pinconning Rd
- 65. Ike's Welding, 50 N Finn Rd
- 68. Williams Township Hall, 1080 W Midland Rd
- 69. Pump Station, 490 W. Salzburg & 9 Mile Rd
- 70. 11 Mile Elevated Tank, 5003 S. 11 Mile Rd
- 72. Lindy's Sales, 9051 M-25

Distribution System Bacteriological							
Water Supplier Bacteriological Analysis Report							
MICHIGAN DEPARTMENT OF PUBLIC HEALTH Bureau of Environmental Health Water Supplier Bacteriological Analysis Report				Name of Water Supply Bay Area Water Treatment Plant			
				June, 2021			
COUNTY	COMMUNITY	WSSN NUMBER	DISTRIBUTION SYSTEM SAMPLES				
			avg free cl2 mg/L	NUMBER REQUIRED	NUMBER COLLECTED	NUMBER POSITIVE	NUMBER REPEAT SAMPLES
Tuscola	Akron	0072	0.45	1	1	0	0
BAY	Bangor Township	0390	0.71	10	10	0	0
BAY	Bangor-Monitor Dist.	0400	0.95	3	3	0	0
BAY	Bay City	0470	0.62	40	49	0	0
BAY	Bay County (Frankl./Monitor/Portsm.)	0485	0.75	10	10	0	0
BAY	Beaver Road Area	0517	0.73	1	1	0	0
BAY	Beaver Township	0518	0.54	2	3	0	0
BAY	Essexville	2180	0.95	4	5	0	0
BAY	Fraser Township	2465	0.84	2	2	0	0
BAY	Hampton Township	2960	0.62	10	12	0	0
BAY	Kawkawlin Township	3565	0.99	3	3	0	0
BAY	Kawkawlin Metro Dist.	3570	0.81	2	2	0	0
BAY	Merritt Township	4280	0.62	2	2	0	0
BAY	Monitor Township	4440	0.80	6	6	0	0
BAY	City of Pinconning	5330	0.47	2	2	0	0
BAY	Pinconning Township	5335	0.83	2	2	0	0
BAY	Portsmouth Township	5540	0.73	1	1	0	0
BAY	Williams Township	7125	0.64	6	8	0	0
Tuscola	Wisner	7134	0.63	1	1	0	0
Average Free Cl2 Residual of All Distribution Sites			0.72	mg/L			
1. Total distribution samples			123				
2. Total distribution samples with detectable free cl2 residual			123				
3. Total distribution samples with no detectable free cl2 residual			0				
4. Total distribution samples with no detectable free cl2 residual and HPC was <500			0				
5. Total distribution samples with no detectable free cl2 residual and HPC was >500			0				
6. Percent of distribution samples with no detectable free cl2 residual			0.00%				
7. Percent shown line #6 in previous monthly report			0.00%				

