

Bay Area WTP

Monthly Operations Report



May, 2023

Water Systems Serial Number: 0465


Ryan Goebel

Water Plant Superintendent
Title

F-1
Classification


Mike Wagar

Operations Supervisor
Title

F-2
Classification

Bay Area Water Treatment Plant

Monthly Operations Report

Supply Name: Bay Area Water System
 WSSN: 0465

Ryan Goebel
 Operator-in-charge

May, 2023
 Month, Year

F-1
 Certification of Operator-in-charge

F-1
 Water Plant Classification

Bay
 County

Treatment Rate and Membrane Data

Treatment Rate, Approved Rated Plant Capacity	<u>17.4</u>	Millions of Gallons per Day
Treatment Rate, Maximum	<u>11.4</u>	Millions of Gallons per Day
Maximum Approved Transmembrane Pressure	<u>22</u>	PSI
Maximum Operating Transmembrane Pressure	<u>14.17</u>	PSI
Maximum Approved Flux Rate	<u>36.25</u>	gpd/sq.ft.
Maximum Operating Flux Rate	<u>27.44</u>	gpd/sq.ft.

Chemical Data

Sodium Hypochlorite on hand:	<u>4,899</u>	Gallons	Estimated Supply:	<u>80.0</u>	days
Caustic Soda on hand:	<u>1,223</u>	Gallons	Estimated Supply:	<u>83.8</u>	days
Corrosion Inhibitor on hand:	<u>859</u>	Gallons	Estimated Supply:	<u>32.6</u>	days
Hydrofluosilicic Acid on hand:	<u>770</u>	Gallons	Estimated Supply:	<u>33.3</u>	days
Aluminum Chlorohydrate on hand:	<u>783</u>	Gallons	Estimated Supply:	<u>113.7</u>	days
Sulfuric Acid on hand:	<u>527</u>	Gallons	Estimated Supply:	<u>263.4</u>	days
Sodium Bisulfite on hand:	<u>782</u>	Gallons	Estimated Supply:	<u>269.8</u>	days
Citric Acid on hand:	<u>3,124</u>	Gallons	Estimated Supply:	<u>249.9</u>	days
Cost of All Chemicals per Million Gallons:	<u>93.49</u>	Dollars			
Estimated Electrical Cost per Million Gallons:		Dollars			
Estimated Natural Gas Cost per Million Gallons:		Dollars			

Remarks

Number of periods of filter confluence turbidity samples > 0.3 NTU	<u>0</u>
Percent of membrane period confluence samples > 0.3 NTU:	<u>0.00%</u>
Was continuous (every 15 minutes) filter monitoring equipment off-line during the month? If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.	<u>No</u>
Did POE disinfectant residual fall below 0.2 ppm during the month? If yes, indicate date(s) and duration on a separate sheet.	<u>No</u>
Was minimum C*T credit achieved for the entire month? If no, indicate on a separate sheet the date(s) not achieved.	<u>Yes</u>
Was continuous POE chlorine residual monitoring equipment off-line during the month? If yes, date(s) and duration will be indicated on the rule page.	<u>No</u>



Notes

Bay Area WTP Monthly Operating Report

Date	Flows								
	Raw Water (MG)			Clarified (MG)	Sludge (MG)	Treated (MG)	Finished Water Pumped (MG)		
	North	South	Total	Total	Total	Total	N. Euclid	Lauria Road	Total
	FIT-1000-1	FIT-1000-2	Calculated	FIT-5520-1	FIT-5180	FIT-4000-1	FIT-4040-1	FIT-4040-2	Calculated
5/1/2023	0.00	6.77	6.77	0.26	0.08	6.69	3.25	3.17	6.42
5/2/2023	0.00	6.92	6.92	0.30	0.08	6.64	3.16	2.99	6.15
5/3/2023	0.00	7.02	7.02	0.30	0.08	6.91	3.25	3.18	6.42
5/4/2023	0.00	7.04	7.04	0.23	0.09	7.03	3.36	3.18	6.54
5/5/2023	0.00	7.05	7.05	0.28	0.08	6.93	3.37	3.21	6.59
5/6/2023	0.00	6.55	6.55	0.28	0.08	6.98	3.32	3.21	6.53
5/7/2023	0.00	6.74	6.74	0.22	0.09	7.16	3.46	3.28	6.74
5/8/2023	0.00	7.40	7.40	0.30	0.16	7.10	3.43	3.22	6.65
5/9/2023	0.00	7.75	7.75	0.30	0.08	7.70	3.78	3.59	7.37
5/10/2023	0.00	8.33	8.34	0.27	0.17	7.91	3.83	3.52	7.35
5/11/2023	0.00	7.95	7.95	0.28	0.11	8.07	3.97	3.63	7.61
5/12/2023	0.00	7.98	7.98	0.30	0.12	8.24	4.08	3.72	7.80
5/13/2023	0.00	8.53	8.53	0.29	0.13	8.05	3.96	3.62	7.58
5/14/2023	0.00	7.18	7.18	0.30	0.08	7.30	3.52	3.36	6.88
5/15/2023	0.00	8.03	8.03	0.30	0.13	8.29	4.10	3.76	7.86
5/16/2023	0.00	9.21	9.21	0.33	0.09	8.48	4.14	3.85	7.99
5/17/2023	0.00	8.16	8.16	0.26	0.20	8.23	4.10	3.73	7.83
5/18/2023	0.00	7.72	7.72	0.34	0.09	8.34	4.09	3.77	7.86
5/19/2023	0.00	8.10	8.10	0.30	0.13	8.01	3.93	3.60	7.54
5/20/2023	0.00	8.24	8.24	0.31	0.08	7.20	3.43	3.29	6.71
5/21/2023	0.00	7.06	7.06	0.29	0.08	7.90	3.85	3.70	7.55
5/22/2023	0.00	8.15	8.15	0.28	0.19	8.63	4.35	3.98	8.33
5/23/2023	0.00	9.62	9.62	0.27	0.15	9.58	4.68	4.22	8.91
5/24/2023	0.00	10.02	10.02	0.28	0.08	8.56	4.26	3.83	8.09
5/25/2023	0.00	7.96	7.96	0.25	0.08	8.65	4.31	3.89	8.20
5/26/2023	0.00	8.53	8.53	0.27	0.08	9.08	4.52	4.11	8.63
5/27/2023	0.00	8.92	8.92	0.30	0.08	8.96	4.39	3.99	8.37
5/28/2023	0.00	9.17	9.17	0.31	0.08	9.13	4.60	4.11	8.71
5/29/2023	0.00	10.03	10.03	0.31	0.08	10.46	5.25	4.71	9.96
5/30/2023	1.95	9.72	11.67	0.34	0.08	11.03	5.61	5.02	10.63
5/31/2023	3.24	8.83	12.07	0.31	0.14	11.44	5.76	5.17	10.92
Total	5.19	250.68	255.87	8.96	3.28	254.70	125.12	115.60	240.72
Avg	0.17	8.09	8.25	0.29	0.11	8.22	4.04	3.73	7.77
Min	0.00	6.55	6.55	0.22	0.08	6.64	3.16	2.99	6.15
Max	3.24	10.03	12.07	0.34	0.20	11.44	5.76	5.17	10.92



Raw Water Analysis								
Date	Temp	pH	Turbidity		F ⁻	Free Cl	Bacti	
	Average	Average	Average	Maximum	Grab	Average	Positive/Negative	
	°C		NTU		mg/L	mg/L	Total Coliform	E. coli
	TIT-1000	AIT-1000-2	AIT-1000-1		Lab	AIT-1035-2	Lab	
5/1/2023	7.4	7.86	0.51	0.66	0.08	0.37	Negative	Negative
5/2/2023	7.4	7.86	0.51	0.78	0.08	0.39	Negative	Negative
5/3/2023	7.4	7.85	0.54	1.13	0.08	0.39	Negative	Negative
5/4/2023	7.3	7.84	0.63	1.25	0.08	0.40	Negative	Negative
5/5/2023	7.3	7.84	0.52	0.64	0.08	0.43	Negative	Negative
5/6/2023	7.4	7.84	0.68	0.98	0.08	0.41	Negative	Negative
5/7/2023	7.6	7.83	0.65	1.64	0.08	0.42	Negative	Negative
5/8/2023	7.9	7.83	0.42	1.71	0.08	0.39	Negative	Negative
5/9/2023	8.1	7.86	0.43	0.54	0.08	0.28	Negative	Negative
5/10/2023	8.6	7.84	0.90	14.69	0.08	0.22	Negative	Negative
5/11/2023	9.1	7.81	0.53	0.82	0.08	0.13	Negative	Negative
5/12/2023	9.5	7.78	0.47	1.65	0.08	0.29	Negative	Negative
5/13/2023	9.7	7.76	0.66	1.41	0.08	0.56	Negative	Negative
5/14/2023	9.8	7.78	0.93	2.91	0.08	0.37	Negative	Negative
5/15/2023	10.6	7.78	0.79	2.13	0.07	0.38	Negative	Negative
5/16/2023	11.3	7.75	0.52	1.41	0.08	0.44	Negative	Negative
5/17/2023	11.3	7.77	0.41	0.72	0.08	0.43	Negative	Negative
5/18/2023	11.3	7.79	1.21	3.24	0.07	0.38	Negative	Negative
5/19/2023	11.4	7.79	0.96	2.29	0.08	0.42	Negative	Negative
5/20/2023	11.4	7.81	0.87	1.54	0.08	0.35	Negative	Negative
5/21/2023	11.5	7.81	0.77	1.48	0.08	0.39	Negative	Negative
5/22/2023	11.8	7.82	0.58	0.94	0.08	0.29	Negative	Negative
5/23/2023	11.9	7.79	0.50	0.73	0.08	0.35	Negative	Negative
5/24/2023	12.1	7.78	0.44	0.70	0.08	0.34	Negative	Negative
5/25/2023	12.0	7.81	0.81	2.48	0.08	0.36	Negative	Negative
5/26/2023	12.2	7.76	1.83	4.61	0.08	0.46	Negative	Negative
5/27/2023	12.4	7.77	0.99	2.05	0.08	0.44	Negative	Negative
5/28/2023	12.7	7.74	0.86	3.14	0.08	0.53	Negative	Negative
5/29/2023	13.0	7.75	0.77	2.35	0.08	0.46	Negative	Negative
5/30/2023	13.5	7.75	0.83	2.61	0.08	0.39	Negative	Negative
5/31/2023	13.9	7.74	1.03	11.08	0.09	0.33	Negative	Negative
Avg	10.3	7.80	0.73	2.40	0.08	0.38	NA	NA
Min	7.3	7.74	0.41	0.54	0.07	0.13	NA	NA
Max	13.9	7.86	1.83	14.69	0.09	0.56	NA	NA



Finished Water Analysis																		
Date	Temp	pH	Phosphate	Fluoride		Free Cl ₂	Alkalinity (as CaCO ₃)		Chloride	Sulfate	Calcium (as CaCO ₃)	Dissolved Oxygen	Conductivity	Langelier Saturation Index	Chloride: Sulfate Mass Ratio	Larson-Skold Index	Bacti	
	Average	Average	Average	Tap	Dist	Average	Carbonate	Bicarbonate	Grab	Grab	Grab	Grab	Grab				Positive/Negative	
	°C		mg/L	mg/L		mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	uS/cm				Total Coliform	E. coli
	AIT-4040-1	AIT-4050-2	AIT-4040-5	Lab		AIT-4050-1	Lab		Lab	Lab	Lab	Lab	Lab				Calculated	
5/1/2023	6.0	7.67	3.37	0.76	0.76	1.00	0	74	10	11	72	12.0	239	-0.91	0.91	0.42	Negative	Negative
5/2/2023	6.3	7.69	3.36	0.77		1.01	0	75	10	10	74	12.4	238	-0.86	1.00	0.40	Negative	Negative
5/3/2023	6.4	7.68	3.37	0.78		1.01	0	74	10	11	74	11.1	237	-0.88	0.91	0.42	Negative	Negative
5/4/2023	6.5	7.65	3.41	0.77		1.01	0	81	9	9	78	12.2	242	-0.84	1.00	0.33	Negative	Negative
5/5/2023	6.5	7.65	3.43	0.76		1.01	0	78	9	9	76	12.4	243	-0.87	1.00	0.35	Negative	Negative
5/6/2023	6.5	7.64	3.43	0.76		1.01	0	77	10	9	70	12.9	245	-0.91	1.11	0.37	Negative	Negative
5/7/2023	6.6	7.64	3.41	0.77		1.01	0	78	10	9	66	11.7	243	-0.94	1.11	0.37	Negative	Negative
5/8/2023	6.9	7.63	3.42	0.78	0.76	1.02	0	78	9	9	66	12.4	243	-0.94	1.00	0.35	Negative	Negative
5/9/2023	7.1	7.63	3.41	0.78		1.01	0	78	10	9	68	11.4	244	-0.92	1.11	0.37	Negative	Negative
5/10/2023	7.7	7.62	3.40	0.77		0.99	0	76	9	12	70	11.1	245	-0.91	0.75	0.41	Negative	Negative
5/11/2023	8.3	7.62	3.41	0.76		0.99	0	76	10	10	74	11.1	252	-0.88	1.00	0.40	Negative	Negative
5/12/2023	8.9	7.60	3.41	0.77		1.00	0	78	10	10	76	10.9	256	-0.86	1.00	0.39	Negative	Negative
5/13/2023	9.2	7.60	3.40	0.76		1.01	0	82	10	9	78	11.5	251	-0.82	1.11	0.35	Negative	Negative
5/14/2023	9.1	7.60	3.39	0.77		1.00	0	81	10	9	78	11.9	247	-0.82	1.11	0.36	Negative	Negative
5/15/2023	9.6	7.60	3.39	0.76	0.77	1.01	0	82	10	10	76	11.7	246	-0.82	1.00	0.37	Negative	Negative
5/16/2023	10.6	7.57	3.39	0.77		1.03	0	80	10	10	74	9.9	248	-0.85	1.00	0.38	Negative	Negative
5/17/2023	10.9	7.59	3.39	0.78		1.03	0	77	10	10	74	10.3	248	-0.84	1.00	0.39	Negative	Negative
5/18/2023	10.8	7.59	3.39	0.75		1.01	0	81	10	8	72	10.9	248	-0.83	1.25	0.34	Negative	Negative
5/19/2023	10.8	7.58	3.40	0.77		1.01	0	79	9	8	70	10.4	248	-0.86	1.13	0.33	Negative	Negative
5/20/2023	10.9	7.58	3.39	0.77		1.00	0	77	9	9	74	11.6	246	-0.84	1.00	0.35	Negative	Negative
5/21/2023	11.0	7.59	3.39	0.78		0.99	0	82	10	9	72	12.6	224	-0.81	1.11	0.35	Negative	Negative
5/22/2023	11.3	7.57	3.39	0.79	0.77	1.01	0	82	10	8	66	10.9	230	-0.86	1.25	0.34	Negative	Negative
5/23/2023	11.4	7.56	3.40	0.78		1.01	0	79	10	9	76	10.7	227	-0.83	1.11	0.37	Negative	Negative
5/24/2023	11.5	7.57	3.40	0.79		1.01	0	79	10	10	76	10.6	224	-0.81	1.00	0.38	Negative	Negative
5/25/2023	11.4	7.60	3.40	0.78		1.02	0	82	10	11	78	11.3	223	-0.75	0.91	0.38	Negative	Negative
5/26/2023	11.5	7.57	3.39	0.78		1.03	0	82	10	11	76	11.2	222	-0.79	0.91	0.38	Negative	Negative
5/27/2023	11.8	7.55	3.40	0.78		1.02	0	81	11	8	78	10.7	221	-0.80	1.38	0.36	Negative	Negative
5/28/2023	12.2	7.52	3.40	0.78		1.01	0	81	11	10	78	10.6	221	-0.82	1.10	0.39	Negative	Negative
5/29/2023	12.5	7.50	3.40	0.79		1.01	0	80	10	10	76	10.8	223	-0.84	1.00	0.38	Negative	Negative
5/30/2023	12.8	7.48	3.40	0.78	0.79	1.02	0	80	10	9	74	10.3	225	-0.87	1.11	0.36	Negative	Negative
5/31/2023	13.2	7.47	3.40	0.79		1.01	0	79	11	12	76	10.5	233	-0.87	0.92	0.44	Negative	Negative
Avg	9.6	7.59	3.40	0.77	0.77	1.01	0	79	10	10	74	11.3	238	-0.85	1.04	0.37	NA	NA
Min	6.0	7.47	3.36	0.75	0.76	0.99	0	74	9	8	66	9.9	221	-0.94	0.75	0.33	NA	NA
Max	13.2	7.69	3.43	0.79	0.79	1.03	0	82	11	12	78	12.9	256	-0.75	1.38	0.44	NA	NA



Date	Turbidity									Finished Water
	Raw Water		Clarified Water	Membrane Feed Water	Combined Membrane Filtrate					
	Avg	Max	Avg	Avg	Avg	Max	# Samples	# > 0.3	% Exceeded	
	NTU									
	AIT-1000-1		AIT-5030-1	AIT-1035-3	AIT-4000-1					Calculated
5/1/2023	0.51	0.66	1.95	0.48	0.022	0.022	96	0	0.0	0.018
5/2/2023	0.51	0.78	2.21	0.48	0.022	0.022	96	0	0.0	0.018
5/3/2023	0.54	1.13	2.06	0.54	0.022	0.022	96	0	0.0	0.019
5/4/2023	0.63	1.25	5.07	0.52	0.022	0.022	96	0	0.0	0.018
5/5/2023	0.52	0.64	1.75	0.50	0.022	0.022	96	0	0.0	0.018
5/6/2023	0.68	0.98	2.12	0.53	0.022	0.022	96	0	0.0	0.018
5/7/2023	0.65	1.64	2.29	0.57	0.022	0.022	96	0	0.0	0.019
5/8/2023	0.42	1.71	2.04	0.42	0.022	0.023	96	0	0.0	0.018
5/9/2023	0.43	0.54	1.96	0.40	0.022	0.023	96	0	0.0	0.018
5/10/2023	0.90	14.69	2.53	0.61	0.022	0.023	96	0	0.0	0.018
5/11/2023	0.53	0.82	2.43	0.49	0.022	0.022	96	0	0.0	0.018
5/12/2023	0.47	1.65	2.32	0.45	0.022	0.022	96	0	0.0	0.018
5/13/2023	0.66	1.41	2.21	0.40	0.022	0.023	96	0	0.0	0.018
5/14/2023	0.93	2.91	2.45	0.51	0.022	0.023	96	0	0.0	0.019
5/15/2023	0.79	2.13	2.90	0.51	0.022	0.023	96	0	0.0	0.018
5/16/2023	0.52	1.41	2.98	0.45	0.022	0.023	96	0	0.0	0.018
5/17/2023	0.41	0.72	2.08	0.36	0.022	0.023	96	0	0.0	0.018
5/18/2023	1.21	3.24	2.48	0.39	0.022	0.023	96	0	0.0	0.018
5/19/2023	0.96	2.29	2.71	0.53	0.022	0.023	96	0	0.0	0.018
5/20/2023	0.87	1.54	2.74	0.49	0.022	0.023	96	0	0.0	0.018
5/21/2023	0.77	1.48	3.49	0.51	0.022	0.023	96	0	0.0	0.018
5/22/2023	0.58	0.94	3.27	0.48	0.022	0.023	96	0	0.0	0.018
5/23/2023	0.50	0.73	3.14	0.55	0.022	0.023	96	0	0.0	0.019
5/24/2023	0.44	0.70	3.05	0.50	0.022	0.023	96	0	0.0	0.019
5/25/2023	0.81	2.48	3.50	0.51	0.022	0.023	96	0	0.0	0.018
5/26/2023	1.83	4.61	3.60	1.29	0.022	0.023	96	0	0.0	0.019
5/27/2023	0.99	2.05	2.33	1.11	0.022	0.023	96	0	0.0	0.019
5/28/2023	0.86	3.14	1.87	0.95	0.022	0.023	96	0	0.0	0.019
5/29/2023	0.77	2.35	2.12	0.81	0.022	0.023	96	0	0.0	0.019
5/30/2023	0.83	2.61	2.52	0.78	0.022	0.023	96	0	0.0	0.019
5/31/2023	1.03	11.08	2.84	0.85	0.022	0.023	96	0	0.0	0.019
Avg	0.73	2.40	2.61	0.58	0.022	0.023	96	0	0.0	0.018
Min	0.41	0.54	1.75	0.36	0.022	0.022	96	0	0.0	0.018
Max	1.83	14.69	5.07	1.29	0.022	0.023	96	0	0.0	0.019

Note: % Exceeded are 4 hr compliance periods where the average of samples are greater than 0.3 NTU



Date	Membrane LRV/Integrity/Max Turbidity																									
	Membrane 1			Membrane 2			Membrane 3			Membrane 4			Membrane 5			Membrane 6			Membrane 7			Membrane 8				
	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity		
	Average	Pass/Fail	Max	Average	Pass/Fail	Max	Average	Pass/Fail	Max	Average	Pass/Fail	Max	Average	Pass/Fail	Max	Average	Pass/Fail	Max	Average	Pass/Fail	Max	Average	Pass/Fail	Max		
psi/min		NTU	psi/min		NTU	psi/min		NTU	psi/min		NTU	psi/min		NTU	psi/min		NTU	psi/min		NTU	psi/min		NTU	psi/min		NTU
5/1/2023	4.27	PASS	0.024	4.22	PASS	0.027	4.38	PASS	0.019	4.61	PASS	0.017	5.42	PASS	0.020	4.47	PASS	0.026	4.45	PASS	0.029	4.85	PASS	0.019		
5/2/2023	4.25	PASS	0.022	4.23	PASS	0.025	4.30	PASS	0.019	4.60	PASS	0.016	5.41	PASS	0.020	4.50	PASS	0.026	4.45	PASS	0.029	4.84	PASS	0.019		
5/3/2023	4.30	PASS	0.020	4.20	PASS	0.025	4.29	PASS	0.019	4.60	PASS	0.016	5.41	PASS	0.020	4.51	PASS	0.024	4.48	PASS	0.029	4.85	PASS	0.020		
5/4/2023	4.32	PASS	0.025	4.18	PASS	0.026	4.31	PASS	0.019	4.58	PASS	0.016	5.41	PASS	0.020	4.46	PASS	0.026	4.43	PASS	0.029	4.85	PASS	0.019		
5/5/2023	4.30	PASS	0.020	4.16	PASS	0.026	4.31	PASS	0.019	4.59	PASS	0.016	5.41	PASS	0.020	4.44	PASS	0.025	4.42	PASS	0.029	4.84	PASS	0.019		
5/6/2023	4.31	PASS	0.020	4.19	PASS	0.028	4.28	PASS	0.019	4.60	PASS	0.016	5.40	PASS	0.020	4.44	PASS	0.025	4.47	PASS	0.029	4.83	PASS	0.020		
5/7/2023	4.30	PASS	0.020	4.18	PASS	0.026	4.29	PASS	0.019	4.63	PASS	0.016	5.52	PASS	0.020	4.49	PASS	0.025	4.51	PASS	0.030	4.83	PASS	0.019		
5/8/2023	4.27	PASS	0.025	4.18	PASS	0.027	4.29	PASS	0.021	4.60	PASS	0.016	5.43	PASS	0.020	4.51	PASS	0.026	4.44	PASS	0.029	4.83	PASS	0.019		
5/9/2023	4.25	PASS	0.020	4.17	PASS	0.027	4.29	PASS	0.022	4.61	PASS	0.016	5.35	PASS	0.021	4.49	PASS	0.025	4.43	PASS	0.029	4.83	PASS	0.019		
5/10/2023	4.24	PASS	0.021	4.18	PASS	0.028	4.27	PASS	0.023	4.61	PASS	0.016	5.36	PASS	0.020	4.51	PASS	0.025	4.46	PASS	0.030	4.83	PASS	0.020		
5/11/2023	4.26	PASS	0.020	4.14	PASS	0.028	4.24	PASS	0.022	4.62	PASS	0.017	5.33	PASS	0.022	4.45	PASS	0.025	4.41	PASS	0.030	4.82	PASS	0.021		
5/12/2023	4.26	PASS	0.026	4.12	PASS	0.027	4.27	PASS	0.022	4.66	PASS	0.017	5.31	PASS	0.021	4.40	PASS	0.025	4.40	PASS	0.029	4.81	PASS	0.021		
5/13/2023	4.22	PASS	0.021	4.12	PASS	0.027	4.25	PASS	0.023	4.63	PASS	0.016	5.31	PASS	0.021	4.45	PASS	0.025	4.40	PASS	0.030	4.82	PASS	0.021		
5/14/2023	4.25	PASS	0.026	4.13	PASS	0.027	4.25	PASS	0.021	4.61	PASS	0.016	5.33	PASS	0.020	4.48	PASS	0.024	4.44	PASS	0.030	4.82	PASS	0.020		
5/15/2023	4.27	PASS	0.026	4.10	PASS	0.027	4.27	PASS	0.021	4.67	PASS	0.017	5.30	PASS	0.020	4.49	PASS	0.024	4.42	PASS	0.030	4.82	PASS	0.021		
5/16/2023	4.25	PASS	0.025	4.08	PASS	0.026	4.26	PASS	0.021	4.63	PASS	0.016	5.28	PASS	0.020	4.43	PASS	0.024	4.41	PASS	0.030	4.82	PASS	0.020		
5/17/2023	4.27	PASS	0.025	4.14	PASS	0.032	4.25	PASS	0.020	4.65	PASS	0.016	5.53	PASS	0.020	4.47	PASS	0.024	4.41	PASS	0.030	4.82	PASS	0.020		
5/18/2023	4.25	PASS	0.020	4.11	PASS	0.026	4.26	PASS	0.020	4.64	PASS	0.016	5.56	PASS	0.020	4.49	PASS	0.023	4.44	PASS	0.029	4.80	PASS	0.019		
5/19/2023	4.18	PASS	0.025	4.12	PASS	0.027	4.27	PASS	0.021	4.62	PASS	0.016	5.37	PASS	0.021	4.46	PASS	0.024	4.52	PASS	0.029	4.83	PASS	0.019		
5/20/2023	4.20	PASS	0.024	4.13	PASS	0.026	4.26	PASS	0.020	4.66	PASS	0.016	5.27	PASS	0.020	4.50	PASS	0.024	4.45	PASS	0.030	4.81	PASS	0.021		
5/21/2023	4.22	PASS	0.025	4.10	PASS	0.025	4.26	PASS	0.020	4.64	PASS	0.016	5.51	PASS	0.020	4.48	PASS	0.024	4.53	PASS	0.030	4.82	PASS	0.021		
5/22/2023	4.18	PASS	0.021	4.09	PASS	0.026	4.29	PASS	0.020	4.64	PASS	0.016	5.40	PASS	0.020	4.45	PASS	0.024	4.42	PASS	0.030	4.80	PASS	0.021		
5/23/2023	4.17	PASS	0.022	4.08	PASS	0.026	4.22	PASS	0.020	4.65	PASS	0.016	5.47	PASS	0.020	4.44	PASS	0.024	4.38	PASS	0.030	4.80	PASS	0.021		
5/24/2023	4.16	PASS	0.022	4.06	PASS	0.026	4.21	PASS	0.020	4.59	PASS	0.016	5.35	PASS	0.020	4.46	PASS	0.025	4.36	PASS	0.029	4.78	PASS	0.020		
5/25/2023	4.17	PASS	0.019	4.04	PASS	0.027	4.22	PASS	0.020	4.48	PASS	0.016	5.16	PASS	0.020	4.41	PASS	0.025	4.35	PASS	0.029	4.76	PASS	0.021		
5/26/2023	4.14	PASS	0.021	4.02	PASS	0.026	4.17	PASS	0.020	4.53	PASS	0.016	5.17	PASS	0.022	4.34	PASS	0.025	4.33	PASS	0.029	4.76	PASS	0.021		
5/27/2023	4.09	PASS	0.022	3.99	PASS	0.026	4.15	PASS	0.020	4.55	PASS	0.016	5.43	PASS	0.020	4.34	PASS	0.026	4.30	PASS	0.029	4.76	PASS	0.021		
5/28/2023	4.08	PASS	0.019	4.03	PASS	0.026	4.15	PASS	0.020	4.47	PASS	0.016	5.57	PASS	0.020	4.35	PASS	0.024	4.34	PASS	0.029	4.77	PASS	0.021		
5/29/2023	4.07	PASS	0.021	3.97	PASS	0.026	4.18	PASS	0.020	4.54	PASS	0.014	5.51	PASS	0.020	4.30	PASS	0.024	4.30	PASS	0.029	4.74	PASS	0.021		
5/30/2023	4.02	PASS	0.021	3.94	PASS	0.026	4.14	PASS	0.020	4.58	PASS	0.014	5.31	PASS	0.022	4.50	PASS	0.024	4.27	PASS	0.029	4.74	PASS	0.021		
5/31/2023	4.03	PASS	0.021	3.92	PASS	0.025	4.10	PASS	0.020	4.53	PASS	0.014	5.11	PASS	0.020	4.44	PASS	0.024	4.28	PASS	0.029	4.74	PASS	0.021		
Avg	4.21		0.022	4.11		0.027	4.25		0.021	4.60		0.016	5.38		0.020	4.45		0.025	4.41		0.029	4.81		0.020		
Min	4.02		0.019	3.92		0.025	4.10		0.019	4.47		0.014	5.11		0.020	4.30		0.023	4.27		0.029	4.74		0.019		
Max	4.32		0.026	4.23		0.032	4.38		0.023	4.67		0.017	5.57		0.022	4.51		0.026	4.53		0.030	4.85		0.021		

*LRV must remain above Upper Control Limit of 3.32 psi/min



Treatment Chemical Dosages											
Date	Treated Water	Sodium Hypochlorite					Phosphoric Acid		Hydrofluorosilicic Acid		
		Raw Water	Membrane Feed Water	Dose pre-FW Tanks	Treated Water	Post FW Tanks	Dose pre-FW Tanks	Post FW Tanks	Raw Water	Dose pre-FW Tanks	Post FW Tanks
	Volume	Free Cl ₂					PO4		F		
	MG	mg/L					mg/L		mg/L		
	FIT-4000-1	AIT-1035-2	AIT-1035-4	Added	AIT-4030-1	AIT-4050-1	Added	AIT-4040-5	Lab	Added	Lab
5/1/2023	6.7	0.37	0.33	0.74	1.06	1.00	3.42	3.37	0.08	0.64	0.76
5/2/2023	6.6	0.39	0.32	0.78	1.08	1.01	3.43	3.36	0.08	0.64	0.77
5/3/2023	6.9	0.39	0.31	0.76	1.07	1.01	3.44	3.37	0.08	0.64	0.78
5/4/2023	7.0	0.40	0.31	0.72	1.07	1.01	3.38	3.41	0.08	0.64	0.77
5/5/2023	6.9	0.43	0.33	0.72	1.07	1.01	3.30	3.43	0.08	0.64	0.76
5/6/2023	7.0	0.41	0.33	0.70	1.07	1.01	3.30	3.43	0.08	0.64	0.76
5/7/2023	7.2	0.42	0.34	0.70	1.07	1.01	3.30	3.41	0.08	0.64	0.77
5/8/2023	7.1	0.39	0.34	0.72	1.07	1.02	3.30	3.42	0.08	0.64	0.78
5/9/2023	7.7	0.28	0.29	0.76	1.06	1.01	3.30	3.41	0.08	0.64	0.78
5/10/2023	7.9	0.22	0.24	0.88	1.06	0.99	3.30	3.40	0.08	0.64	0.77
5/11/2023	8.1	0.13	0.10	1.00	1.08	0.99	3.30	3.41	0.08	0.64	0.76
5/12/2023	8.2	0.29	0.11	0.90	1.11	1.00	3.30	3.41	0.08	0.64	0.77
5/13/2023	8.1	0.56	0.27	0.72	1.10	1.01	3.30	3.40	0.08	0.64	0.76
5/14/2023	7.3	0.37	0.33	0.80	1.08	1.00	3.30	3.39	0.08	0.64	0.77
5/15/2023	8.3	0.38	0.26	0.84	1.11	1.01	3.30	3.39	0.07	0.64	0.76
5/16/2023	8.5	0.44	0.30	0.82	1.12	1.03	3.30	3.39	0.08	0.64	0.77
5/17/2023	8.2	0.43	0.33	0.73	1.10	1.03	3.30	3.39	0.08	0.64	0.78
5/18/2023	8.3	0.38	0.30	0.68	1.08	1.01	3.30	3.39	0.07	0.64	0.75
5/19/2023	8.0	0.42	0.30	0.70	1.09	1.01	3.30	3.40	0.08	0.64	0.77
5/20/2023	7.2	0.35	0.29	0.74	1.07	1.00	3.30	3.39	0.08	0.64	0.77
5/21/2023	7.9	0.39	0.26	0.82	1.09	0.99	3.30	3.39	0.08	0.64	0.78
5/22/2023	8.6	0.29	0.23	0.86	1.09	1.01	3.30	3.39	0.08	0.64	0.79
5/23/2023	9.6	0.35	0.24	0.85	1.10	1.01	3.30	3.40	0.08	0.64	0.78
5/24/2023	8.6	0.34	0.24	0.87	1.09	1.01	3.30	3.40	0.08	0.64	0.79
5/25/2023	8.7	0.36	0.25	0.86	1.10	1.02	3.30	3.40	0.08	0.64	0.78
5/26/2023	9.1	0.46	0.29	0.72	1.11	1.03	3.30	3.39	0.08	0.64	0.78
5/27/2023	9.0	0.44	0.32	0.70	1.08	1.02	3.30	3.40	0.08	0.64	0.78
5/28/2023	9.1	0.53	0.36	0.66	1.09	1.01	3.30	3.40	0.08	0.64	0.78
5/29/2023	10.5	0.46	0.37	0.70	1.09	1.01	3.30	3.40	0.08	0.64	0.79
5/30/2023	11.0	0.39	0.33	0.70	1.08	1.02	3.30	3.40	0.08	0.64	0.78
5/31/2023	11.4	0.33	0.27	0.74	1.08	1.01	3.30	3.40	0.09	0.64	0.79
Avg	8.2	0.38	0.29	0.77	1.08	1.01	3.32	3.40	0.08	0.64	0.77
Min	6.6	0.13	0.10	0.66	1.06	0.99	3.30	3.36	0.07	0.64	0.75
Max	11.4	0.56	0.37	1.00	1.12	1.03	3.44	3.43	0.09	0.64	0.79



Disinfection CT														
Date	Pipeline CT				FW Tank CT						Compliance			
	Whitestone	Travel Time	Residual	CT	FW Tank 1	FW Tank 2	Plant	Contact Time	Free Cl ₂	CT	Total CT	Temp	CT	CT
	Flow	Min	RW	Achieved	Min Level	Min Level	Flow	Min	Min	Achieved	Achieved	Avg	Required	Met
	MGD	Minutes	mg/L	mg-min/L	ft	ft	MGD	Minutes	mg/L	mg-min/L	mg-min/L	°C	mg-min/L	Y/N
Entry	Calculated	AIT-1035-2	Calculated	LIT-4005-1	LIT-4005-2	Calculated	Calculated	Calculated	Calculated	Calculated	Calculated	TIT-1000	Calculated	Calculated
5/1/2023	43.3	2,887	0.37	1070	28.7	22.7	6.4	548	0.98	536	1607	7.4	8.00	Y
5/2/2023	37.5	3,336	0.39	1288	28.7	22.8	6.2	574	0.98	565	1853	7.4	8.00	Y
5/3/2023	40.5	3,089	0.39	1191	28.7	24.1	6.4	564	0.99	560	1750	7.4	8.00	Y
5/4/2023	38.0	3,292	0.40	1325	28.7	24.7	6.5	559	0.98	546	1871	7.3	8.00	Y
5/5/2023	41.3	3,027	0.43	1287	28.7	25.0	6.6	559	0.98	551	1838	7.3	8.00	Y
5/6/2023	52.1	2,400	0.41	991	28.7	25.0	6.5	564	0.99	559	1550	7.4	8.00	Y
5/7/2023	50.1	2,498	0.42	1060	28.6	22.5	6.7	519	0.98	511	1571	7.6	8.00	Y
5/8/2023	43.0	2,909	0.39	1140	28.6	25.1	6.6	554	0.98	542	1681	7.9	8.00	Y
5/9/2023	42.0	2,978	0.28	830	28.6	22.5	7.4	475	0.98	468	1298	8.1	8.00	Y
5/10/2023	43.1	2,900	0.22	626	28.6	23.5	7.4	486	0.95	461	1088	8.6	8.00	Y
5/11/2023	40.3	3,108	0.13	397	28.7	25.0	7.6	484	0.97	470	867	9.1	8.00	Y
5/12/2023	42.5	2,941	0.29	843	28.7	24.8	7.8	470	0.96	450	1294	9.5	8.00	Y
5/13/2023	60.4	2,072	0.56	1158	28.7	24.1	7.6	477	0.97	463	1621	9.7	8.00	Y
5/14/2023	60.0	2,085	0.37	764	28.7	25.2	6.9	536	0.98	524	1288	9.8	8.00	Y
5/15/2023	48.3	2,590	0.38	978	28.8	23.9	7.9	459	0.96	443	1421	10.6	6.00	Y
5/16/2023	46.3	2,705	0.44	1197	28.7	24.9	8.0	459	0.99	455	1653	11.3	6.00	Y
5/17/2023	46.8	2,676	0.43	1155	28.6	24.6	7.8	466	1.01	472	1627	11.3	6.00	Y
5/18/2023	45.0	2,780	0.38	1065	28.6	24.9	7.9	467	0.98	457	1521	11.3	6.00	Y
5/19/2023	48.5	2,577	0.42	1080	28.7	23.7	7.5	477	0.98	466	1546	11.4	6.00	Y
5/20/2023	56.3	2,224	0.35	774	28.6	22.0	6.7	516	0.98	505	1279	11.4	6.00	Y
5/21/2023	54.0	2,316	0.39	892	28.7	24.8	7.6	486	0.95	462	1354	11.5	6.00	Y
5/22/2023	49.0	2,555	0.29	736	28.7	21.3	8.3	412	0.98	403	1138	11.8	6.00	Y
5/23/2023	51.6	2,425	0.35	840	28.8	21.3	8.9	386	0.99	380	1220	11.9	6.00	Y
5/24/2023	52.8	2,371	0.34	806	28.7	25.2	8.1	457	0.99	450	1257	12.1	6.00	Y
5/25/2023	47.6	2,626	0.36	934	28.8	23.7	8.2	439	1.01	442	1376	12.0	6.00	Y
5/26/2023	48.5	2,579	0.46	1195	28.7	24.8	8.6	425	0.99	418	1613	12.2	6.00	Y
5/27/2023	61.0	2,051	0.44	905	28.8	24.9	8.4	439	0.98	430	1335	12.4	6.00	Y
5/28/2023	62.3	2,009	0.53	1057	28.7	25.6	8.7	428	0.99	421	1479	12.7	6.00	Y
5/29/2023	58.5	2,138	0.46	985	28.9	22.5	10.0	354	0.98	346	1331	13.0	6.00	Y
5/30/2023	60.4	2,072	0.39	818	29.0	23.1	10.6	336	0.96	322	1140	13.5	6.00	Y
5/31/2023	65.0	1,924	0.33	632	29.1	24.0	10.9	333	0.97	324	956	13.9	6.00	Y
Avg	49.5	2,585	0.38	968	28.7	23.9	7.8	474	0.98	465	1433	10.3	6.90	NA
Min	37.5	1,924	0.13	397	28.6	21.3	6.2	333	0.95	322	867	7.3	6.00	NA
Max	65.0	3,336	0.56	1325	29.1	25.6	10.9	574	1.01	565	1871	13.9	8.00	NA



Notes:

Pipeline volume factor in SMMWSC to RW tank: 125,090 MG-min/day

Distribution System Monitoring																								
Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl2)																								
WSSN:	0072	0390				0400			0470							0485					0517	0518		2180
	Akron	Bangor Twp.				Bangor Monitor Dist.			Bay City							Bay County					Beaver Rd	Beaver Twp		Essexville
Date	1	3	4	5	6	7	9	10	11	12	13	14	15	16	17	18	19	20	23	24	26	29	30	32
5/1/2023	0.30	0.38	0.62	0.58	0.94				0.86	0.58	0.75	0.84	0.42	0.95	0.79	0.79	0.85	0.79	0.63	0.64				0.97
5/2/2023																						0.50		
5/3/2023																								
5/4/2023						0.85	0.92		0.81	0.55	0.64	0.78	0.46	0.99	0.67									
5/5/2023																								
5/6/2023																								
5/7/2023																								
5/8/2023																								0.89
5/9/2023																0.72	0.78	0.78	0.83			0.51		
5/10/2023									0.86	0.61	0.71	0.83	0.41	0.98	0.69									
5/11/2023				0.34	0.87			0.88																
5/12/2023																								
5/13/2023																								
5/14/2023																								
5/15/2023									0.83	0.58	0.71	0.81	0.40	0.96	0.76					0.55	0.82			0.97
5/16/2023																								
5/17/2023									0.84	0.57	0.73	0.84	0.41	0.98	0.69									
5/18/2023		0.38	0.42	0.48	0.88																			
5/19/2023																								
5/20/2023																								
5/21/2023																								
5/22/2023																								0.90
5/23/2023																								
5/24/2023									0.83	0.56	0.68	0.85	0.33	0.91	0.69									
5/25/2023																								
5/26/2023																								
5/27/2023																								
5/28/2023																								
5/29/2023																								
5/30/2023									0.84	0.58	0.67	0.74	0.41	0.94	0.68									
5/31/2023																								
Average	0.30			0.59				0.88				0.71						0.74			0.82		0.51	0.93
Min	0.30			0.34				0.85				0.33						0.55			0.82		0.50	0.89
Max	0.30			0.94				0.92				0.99						0.85			0.82		0.51	0.97



MONITORING STATION ADDRESSES

- | | | |
|--|---|---|
| 1. Sample station at corner of 5758 M-25 & R | 11. Number 1 Fire Station, 1401 Center Ave | 19. Dore's M-84 Party Store, 6183 WS Saginaw Rd |
| 3. Bangor Fire Station, 3921 Wheeler | 12. Number 2 Fire Station, 1000 Fremont Ave | 20. Pump Station #13, 6000 WS Saginaw Rd |
| 4. BCDWS Admin. Bldg. 3933 Patterson Rd. | 13. Jack's Fruit Market, 1000 Salzburg Ave | 23. Rail Trail Pump Station, 366 N. Tuscola Rd. |
| 5. 7-11, 3543 S. Old Kawkawlin Rd. | 14. Number 4 Fire Station, 212 S. Dean St | 24. Little Learners Daycare, 1694 Cass Ave. |
| 6. Admiral Petroleum, 314 S Euclid Ave. | 15. Number 5 Fire Station, 1209 Smith St | 26. Wieland Contracting, 2443 S Mackinaw Rd |
| 7. Sequin Lumber, 3881 Euclid Ave | 16. Bay City Hall, 301 Washington Ave | 29. Sample Station, 2515 S. 11 Mile Rd |
| 9. B's Boutique, 2981 Midland Rd | 17. Skipper Buds Marina, 1809 S Water St | 30. Sample Station, 340 W. Beaver Rd |
| 10. Little Caesars, 3475 E North Union Rd | 18. Bay Valley Animal Hospital 6015 WS Saginaw Rd | 32. Essexville City Hall, 1107 Woodside Ave |

Distribution System Monitoring																								
Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl ₂)																								
WSSN:	2465		2960			3565			3570		4280		4440			5330		5335		5540	7125			7134
Date	Fraser Twp.		Hampton Twp.			Kawkawlin Twp.			Kawkawlin Met.		Merritt Twp.		Monitor Twp.			City Pinconning		Pinconning Twp.		Portsmouth	Williams Twp.			Wisner
	34	35	37	38	39	40	41	42	43	45	46	48	49	52	55	58	59	61	63	65	68	69	70	72
5/1/2023																								
5/2/2023												0.57								0.63	0.68	0.59	0.50	0.47
5/3/2023																								
5/4/2023		0.80				0.85	0.72		0.72				0.89	0.72	0.67	0.58		0.60						
5/5/2023			0.67	0.52	0.55																			
5/6/2023																								
5/7/2023																								
5/8/2023																								
5/9/2023												0.57									0.45	0.61	0.42	
5/10/2023																								
5/11/2023														0.83	0.71	0.72								
5/12/2023			0.50	0.66	0.49																			
5/13/2023																								
5/14/2023																								
5/15/2023																								
5/16/2023	0.53							0.77	0.60							0.51		0.58						
5/17/2023																								
5/18/2023			0.50	0.58	0.47																			
5/19/2023																								
5/20/2023																								
5/21/2023																								
5/22/2023																								
5/23/2023																								
5/24/2023																								
5/25/2023																								
5/26/2023			0.49																					
5/27/2023																								
5/28/2023																								
5/29/2023																								
5/30/2023																								
5/31/2023																								
Average	0.67		0.54			0.78			0.66		0.57		0.76			0.55		0.59		0.63		0.54		0.47
Min	0.53		0.47			0.72			0.60		0.57		0.67			0.51		0.58		0.63		0.42		0.47
Max	0.80		0.67			0.85			0.72		0.57		0.89			0.58		0.60		0.63		0.68		0.47



MONITORING STATION ADDRESSES

- 34. Fraser Elevated Tank, 2949 1/2 N. Huron Rd
- 35. Lloyd's Cabinet, 1947 N Huron Rd
- 37. Hampton DPW, 950 Wagner Rd.
- 38. Bay County Golf Course, 584 W Hampton Rd.
- 39. Sewer Lift Station, 902 Nebobish Rd.
- 40. Bay Co. Road Commision, 2600 E Beaver Rd
- 41. Parish Rd. Elevated Tank, 1770 E. Parish Rd
- 42. Linwood Tile, 205 S Huron Rd

- 43. Speedway, 106 S. Huron Rd.
- 45. Kawkawlin Restaurant, 103 S Huron Rd
- 46. John's Bar, 1476 S Tuscola Rd
- 48. Tool Shed Bar, 12 W Munger Rd
- 49. Wilder Rd Party Store, 2951 E Wilder Rd
- 52. Monitor Twp. Elevated Tank, 1611 E. Midland Rd
- 55. Auburn Fertilizer, 4640 S 7 Mile Rd
- 58. Pinconning City Hall, 208 S Manitou St

- 59. Marathon Gas Station, 511 S Mabel St
- 61. Pinconning Meter Pit, 3005 N Huron Rd
- 63. Master Meter Pit, 2865 Pinconning Rd
- 65. Ike's Welding, 50 N Finn Rd
- 68. Williams Township Hall, 1080 W Midland Rd
- 69. Pump Station, 490 W. Salzburg & 9 Mile Rd
- 70. 11 Mile Elevated Tank, 5003 S. 11 Mile Rd
- 72. Lindy's Sales, 9051 M-25

Distribution System Bacteriological							
Water Supplier Bacteriological Analysis Report							
MICHIGAN DEPARTMENT OF PUBLIC HEALTH Bureau of Environmental Health Water Supplier Bacteriological Analysis Report				Name of Water Supply			
				Bay Area Water Treatment Plant			
				May, 2023			
COUNTY	COMMUNITY	WSSN NUMBER	DISTRIBUTION SYSTEM SAMPLES				
			avg free cl2 mg/L	NUMBER REQUIRED	NUMBER COLLECTED	NUMBER POSITIVE	NUMBER REPEAT SAMPLES
Tuscola	Akron	0072	0.30	1	1	0	0
BAY	Bangor Township	0390	0.59	10	10	0	0
BAY	Bangor-Monitor Dist.	0400	0.88	3	3	0	0
BAY	Bay City	0470	0.71	30	49	0	0
BAY	Bay County (Frankl./Monitor/Portsm.)	0485	0.74	9	10	0	0
BAY	Beaver Road Area	0517	0.82	1	1	0	0
BAY	Beaver Township	0518	0.51	2	2	0	0
BAY	Essexville	2180	0.93	4	4	0	0
BAY	Fraser Township	2465	0.67	2	2	0	0
BAY	Hampton Township	2960	0.54	10	10	0	0
BAY	Kawkawlin Township	3565	0.78	3	3	0	0
BAY	Kawkawlin Metro Dist.	3570	0.66	2	2	0	0
BAY	Merritt Township	4280	0.57	2	2	0	0
BAY	Monitor Township	4440	0.76	6	6	0	0
BAY	City of Pinconning	5330	0.55	2	2	0	0
BAY	Pinconning Township	5335	0.59	2	2	0	0
BAY	Portsmouth Township	5540	0.63	1	1	0	0
BAY	Williams Township	7125	0.54	6	6	0	0
Tuscola	Wisner	7134	0.47	1	1	0	0
Average Free Cl2 Residual of All Distribution Sites			0.64	mg/L			
1. Total distribution samples					117		
2. Total distribution samples with detectable free cl2 residual					117		
3. Total distribution samples with no detectable free cl2 residual					0		
4. Total distribution samples with no detectable free cl2 residual and HPC was <500					0		
5. Total distribution samples with no detectable free cl2 residual and HPC was >500					0		
6. Percent of distribution samples with no detectable free cl2 residual					0.00%		
7. Percent shown line #6 in previous monthly report					0.00%		

