Bay Area WTP

Monthly Operations Report

September, 2026

Water Systems Serial Number: 0465

Carl J. Overly	Water Plant Superintendent	F-1, S-3, D-2
	Title	Classification
Mike Wagar	Operations Supervisor	F-1, S-4
	Title	Classification

Bay Area Water Treatment Plant

Monthly Operations Report

Supply Name: Bay Area Water System
WSSN: 0465

Carl J. Overly	September, 2026
Operator-in-charge	Month, Year
F-1, S-3, D-2	F-1
Certification of Operator-in-charge	Water Plant Classification
20001	Bay
Operator identification Number for Operator-in-charge	County

Treatment Rate and Membrane Data

Treatment Rate, Approved Rated Plant Capacity	17.4	Millions of Gallons per Day
Treatment Rate, Maximum	9.1	Millions of Gallons per Day
Maximum Approved Transmembrane Pressure	22	PSI
Maximum Operating Transmembrane Pressure	14.59	PSI
Maximum Approved Flux Rate	36.25	gpd/sq.ft.
Maximum Operating Flux Rate	28.55	gpd/sq.ft.

Chemical Data

Sodium Hypochlorite on hand:	2,593	Gallons	Estimated Supply:	27.4	days
Caustic Soda on hand:	2,143	Gallons	Estimated Supply:	146.8	days
Corrosion Inhibitor on hand:	456	Gallons	Estimated Supply:	18.2	days
Hydrofluosilicic Acid on hand:	961	Gallons	Estimated Supply:	50.1	days
Aluminum Chlorohydrate on hand:	561	Gallons	Estimated Supply:	219.2	days
Sulfuric Acid on hand:	122	Gallons	Estimated Supply:	61.0	days
Sodium Bisulfite on hand:	934	Gallons	Estimated Supply:	322.0	days
Citric Acid on hand:	1,080	Gallons	Estimated Supply:	86.4	days
Cost of All Chemicals per Million Gallons:	95.94	Dollars			

Utility Data

Estimated Electrical Kilo Watts per Million Gallons:	934.86	KW
Estimated Natural Gas Million Cubic Feet per Million Gallons:	2.35	Mcf

Remarks

Number of periods of filter confluence turbidity samples > 0.3 NTU	0
Percent of membrane period confluence samples > 0.3 NTU:	0.00%
Was continuous (every 15 minutes) filter monitoring equipment off-line during the month? If yes, indicate date(s), duration, and individual filter grab sampling frequency on a separate sheet.	No
Did POE disinfectant residual fall below 0.2 ppm during the month? If yes, indicate date(s) and duration on a separate sheet.	No
Was minimum C*T credit achieved for the entire month? If no, indicate on a separate sheet the date(s) not achieved.	Yes
Was continuous POE chlorine residual monitoring equipment off-line during the month? If yes, date(s) and duration will be indicated on the rule page.	No

Notes

Akron's BacT sample on 9/1 had a free chlorine residual below 0.1 mg/L. HPCs were run on the sample the CFU count were 7/1.

On 9/25 at 20:00 the online PO4 analyzer experienced a failure due its reagaents. Shortly after putting a new batch in, the reading spiked high and wouldn't come back down. In response to the event, a new batch of reagents were made but take time climatize the filter floors temp. In the meantime, operations did grab samples every 4 hours to monitor PO4 levels. The new reagents were ready to go by 14:33 on 9/26 and the unit was put back into service.

On 9/28 the Fraser water tower was placed back into service. The Tower has been out since early August for a new interior coating system installed by USG.

Bay Area WTP Monthly Operating Report

Flows									
	Raw Water (MG)			Clarified (MG)	Sludge (MG)	Treated (MG)	Finished Water Pumped (MG)		
	N. Euclid	Lauria Road	Total	Total	Total	Total	N. Euclid	Lauria Road	Total
Date	FIT-1000-1	FIT-1000-2	Calculated	FIT-5520-1	FIT-5180	FIT-4000-1	FIT-4040-1	FIT-4040-2	Calculated
9/1/2026	3.06	5.37	8.43	0.11	0.16	8.43	4.33	3.43	7.76
9/2/2026	3.08	5.84	8.91	0.18	0.14	8.72	4.45	3.54	7.99
9/3/2026	3.10	5.69	8.79	0.23	0.08	8.41	4.31	3.42	7.73
9/4/2026	3.09	4.33	7.42	0.21	0.08	7.53	3.79	3.10	6.89
9/5/2026	3.49	3.76	7.26	0.18	0.08	7.17	3.63	2.97	6.59
9/6/2026	3.35	3.74	7.09	0.18	0.08	7.38	3.65	2.97	6.62
9/7/2026	2.99	5.52	8.51	0.18	0.08	8.35	4.24	3.42	7.66
9/8/2026	3.04	4.56	7.59	0.24	0.08	8.14	4.19	3.34	7.52
9/9/2026	3.02	5.74	8.76	0.24	0.08	8.49	4.29	3.42	7.70
9/10/2026	3.03	5.69	8.72	0.17	0.08	8.84	4.62	3.72	8.34
9/11/2026	3.11	6.29	9.41	0.16	0.20	9.10	4.58	3.71	8.29
9/12/2026	1.90	6.45	8.36	0.16	0.09	8.16	4.09	3.30	7.39
9/13/2026	1.77	4.42	6.20	0.21	0.08	7.54	3.95	3.24	7.19
9/14/2026	3.85	5.48	9.33	0.24	0.08	8.59	4.30	3.43	7.73
9/15/2026	2.86	5.48	8.34	0.22	0.08	7.86	3.97	3.24	7.21
9/16/2026	0.00	7.37	7.37	0.18	0.08	8.07	4.11	3.32	7.43
9/17/2026	0.00	8.66	8.66	0.12	0.17	7.72	3.92	3.24	7.16
9/18/2026	0.00	7.58	7.58	0.02	0.25	8.11	4.02	3.37	7.39
9/19/2026	0.00	7.66	7.66	0.09	0.21	7.19	3.63	2.99	6.61
9/20/2026	0.00	6.78	6.78	0.21	0.08	7.04	3.54	2.89	6.43
9/21/2026	0.00	7.69	7.69	0.05	0.24	7.75	3.96	3.16	7.12
9/22/2026	0.00	8.20	8.20	0.15	0.14	7.76	3.94	3.14	7.09
9/23/2026	0.00	7.54	7.54	0.18	0.08	8.00	4.04	3.25	7.29
9/24/2026	0.00	7.85	7.85	0.18	0.08	7.30	3.69	2.98	6.68
9/25/2026	0.00	6.97	6.97	0.09	0.19	7.53	3.83	3.07	6.90
9/26/2026	0.00	7.61	7.61	0.03	0.25	7.07	3.58	2.84	6.42
9/27/2026	0.00	7.24	7.24	0.03	0.25	7.50	3.90	3.16	7.05
9/28/2026	0.00	8.24	8.24	0.10	0.25	8.58	4.26	3.43	7.70
9/29/2026	0.00	8.79	8.79	0.13	0.17	8.10	4.12	3.28	7.40
9/30/2026	0.00	8.07	8.07	0.21	0.08	7.89	4.05	3.24	7.29
Total	44.74	194.62	239.36	4.71	4.04	238.32	120.98	97.60	218.58
Avg	1.49	6.49	7.98	0.16	0.13	7.94	4.03	3.25	7.29
Min	0.00	3.74	6.20	0.02	0.08	7.04	3.54	2.84	6.42
Max	3.85	8.79	9.41	0.24	0.25	9.10	4.62	3.72	8.34

Recovery Process Efficiency
Sludge Flow / Recovery Flow
46.2%

Facility Water Efficiency		
Waste (MG)	Treated (MG)	T/W (G)
9.29	238.32	25.6

Raw Water Analysis								
	Temp	pH	Turbidity		F^-	Free Cl	Bacti	
	Average	Average	Average	Maximum	Grab	Average	Positive/Negative	
	°C		NTU		mg/L	mg/L	Total Coliform	E. coli
Date	TIT-1000	AIT-1000-2	AIT-1000-1		Lab - Mem Feed	AIT-1035-2	Lab	
9/1/2026	9.0	7.97	0.47	0.69	0.09	0.29	Negative	Negative
9/2/2026	9.0	7.93	0.44	0.50	0.09	0.32	Negative	Negative
9/3/2026	9.0	7.98	0.41	0.45	0.09	0.31	Negative	Negative
9/4/2026	9.0	8.00	0.41	0.57	0.09	0.29	Negative	Negative
9/5/2026	9.1	8.01	0.50	0.66	0.09	0.28	Negative	Negative
9/6/2026	9.1	8.02	0.57	0.76	0.09	0.34	Negative	Negative
9/7/2026	9.2	8.14	0.74	0.91	0.09	0.15	Negative	Negative
9/8/2026	9.2	8.12	0.65	0.77	0.09	0.13	Negative	Negative
9/9/2026	9.3	8.05	0.83	1.45	0.09	0.10	Negative	Negative
9/10/2026	9.2	8.00	1.00	4.05	0.09	0.06	Negative	Negative
9/11/2026	9.1	7.94	0.99	2.45	0.09	0.06	Negative	Negative
9/12/2026	9.0	7.90	1.00	1.17	0.09	0.11	Negative	Negative
9/13/2026	8.7	7.83	0.79	1.04	0.09	0.15	Negative	Negative
9/14/2026	8.6	7.91	0.92	10.01	0.09	0.18	Negative	Negative
9/15/2026	8.6	7.93	0.75	0.91	0.09	0.21	Negative	Negative
9/16/2026	8.5	7.88	0.82	1.25	0.09	0.23	Negative	Negative
9/17/2026	8.2	7.84	1.10	1.46	0.09	0.34	Negative	Negative
9/18/2026	8.4	7.94	1.05	1.20	0.09	0.25	Negative	Negative
9/19/2026	8.4	7.95	1.12	1.50	0.09	0.31	Negative	Negative
9/20/2026	8.4	7.95	0.93	1.25	0.09	0.35	Negative	Negative
9/21/2026	8.4	7.94	0.71	0.94	0.09	0.42	Negative	Negative
9/22/2026	8.3	7.93	2.23	8.78	0.09	0.49	Negative	Negative
9/23/2026	8.2	7.91	6.13	7.71	0.09	0.16	Negative	Negative
9/24/2026	8.2	7.94	5.84	10.01	0.09	0.10	Negative	Negative
9/25/2026	8.1	7.98	5.90	8.47	0.10	0.06	Negative	Negative
9/26/2026	8.0	7.95	3.69	5.02	0.08	0.15	Positive	Negative
9/27/2026	7.9	7.96	2.35	5.78	0.10	0.28	Negative	Negative
9/28/2026	7.9	7.99	1.69	1.99	0.09	0.35	Negative	Negative
9/29/2026	7.9	7.99	1.26	1.89	0.09	0.44	Negative	Negative
9/30/2026	8.0	7.99	0.80	1.16	0.09	0.52	Negative	Negative
Avg	8.6	7.96	1.54	2.83	0.09	0.25	NA	NA
Min	7.9	7.83	0.41	0.45	0.08	0.06	NA	NA
Max	9.3	8.14	6.13	10.01	0.10	0.52	NA	NA

F^- Ratio, Raw/Tap:
12.9

Finished Water Analysis																			
	Temp	pH	Phosphate	Fluoride		Free Cl_2	Hardness	Alkalinity (as $CaCO_3$)		Chloride	Sulfate	Calcium (as $CaCO_3$)	Dissolved Oxygen	Conductivity	Langelier Saturation Index	Chloride: Sulfate Mass Ratio	Larson-Skold Index	Bacti	
	Average	Average	Average	Tap	Dist	Average	Grab	Carbonate	Bicarbonate	Grab	Grab	Grab	Grab	Grab				Positive/Negative	
	°C		mg/L	mg/L		mg/L	mg/L	mg/L		mg/L	mg/L	mg/L	mg/L	uS/cm				Total Coliform	E. coli
Date	AIT-4040-1	AIT-4050-2	AIT-4040-5	Lab		AIT-4050-1	Lab	Lab		Lab	Lab	Lab	Lab	Lab	Calculated			Lab	
9/1/2026	21.1	7.55	3.32	0.71		1.32	104.40	0	74	11	10	77	8.8	272	-0.65	1.10	0.43	Negative	Negative
9/2/2026	21.0	7.53	3.43	0.69		1.32	97.80	0	74	11	10	72	8.5	270	-0.69	1.06	0.42	Negative	Negative
9/3/2026	20.9	7.51	3.43	0.69		1.32	100.00	0	75	12	10	70	9.0	269	-0.72	1.20	0.45	Negative	Negative
9/4/2026	20.8	7.52	3.42	0.69		1.30	100.00	0	75	11	9	74	8.7	269	-0.69	1.27	0.42	Negative	Negative
9/5/2026	20.8	7.54	3.40	0.69		1.29	100.00	0	75	12	10	72	10.8	271	-0.68	1.16	0.44	Negative	Negative
9/6/2026	21.0	7.55	3.40	0.69		1.30	96.60	0	75	11	10	71	10.9	271	-0.67	1.09	0.42	Negative	Negative
9/7/2026	21.2	7.55	3.41	0.69		1.31	100.20	0	74	11	10	73	10.9	275	-0.66	1.09	0.43	Negative	Negative
9/8/2026	21.4	7.58	3.40	0.69	0.69	1.28	102.80	0	76	11	11	75	11.0	280	-0.60	1.02	0.44	Negative	Negative
9/9/2026	21.6	7.59	3.40	0.70		1.30	99.20	0	75	11	10	75	10.8	227	-0.58	1.07	0.42	Negative	Negative
9/10/2026	21.5	7.58	3.40	0.71		1.29	106.00	0	80	14	9	78	8.4	231	-0.55	1.53	0.44	Negative	Negative
9/11/2026	21.4	7.57	3.39	0.70		1.28	106.00	0	80	15	10	78	8.8	253	-0.57	1.47	0.48	Negative	Negative
9/12/2026	21.2	7.55	3.38	0.71		1.29	104.00	0	79	14	10	76	8.2	230	-0.61	1.41	0.47	Negative	Negative
9/13/2026	20.9	7.54	3.38	0.69		1.28	106.00	0	79	12	11	77	8.2	229	-0.62	1.07	0.44	Negative	Negative
9/14/2026	20.1	7.53	3.39	0.68		1.31	101.90	0	76	11	11	67	8.8	226	-0.72	1.00	0.44	Negative	Negative
9/15/2026	19.7	7.54	3.37	0.69		1.32	102.60	0	76	11	11	69	8.6	227	-0.71	1.04	0.45	Negative	Negative
9/16/2026	19.7	7.54	3.37	0.69		1.31	108.00	0	75	11	10	68	8.3	227	-0.72	1.12	0.43	Negative	Negative
9/17/2026	19.2	7.53	3.36	0.70		1.33	106.00	0	79	13	10	78	9.3	227	-0.66	1.32	0.45	Negative	Negative
9/18/2026	18.7	7.53	3.35	0.71		1.32	112.00	0	80	14	11	82	8.9	229	-0.64	1.30	0.49	Negative	Negative
9/19/2026	18.8	7.55	3.36	0.71		1.29	109.60	0	79	13	12	86	9.0	230	-0.60	1.04	0.47	Negative	Negative
9/20/2026	19.0	7.56	3.36	0.71		1.31	102.00	0	76	13	12	82	8.6	228	-0.63	1.06	0.49	Negative	Negative
9/21/2026	18.9	7.57	3.37	0.70	0.71	1.34	102.00	0	77	13	13	80	8.9	226	-0.62	0.98	0.50	Negative	Negative
9/22/2026	18.8	7.58	3.36	0.70		1.34	104.00	0	78	13	15	84	8.7	220	-0.59	0.83	0.52	Negative	Negative
9/23/2026	18.8	7.57	3.36	0.70		1.30	102.00	0	77	12	10	77	8.9	220	-0.64	1.21	0.44	Negative	Negative
9/24/2026	18.6	7.56	3.36	0.68		1.32	97.20	0	75	12	10	67	9.1	223	-0.73	1.16	0.44	Negative	Negative
9/25/2026	18.4	7.57	3.36	0.70		1.29	101.60	0	78	11	12	71	9.3	232	-0.68	0.92	0.44	Negative	Negative
9/26/2026	18.2	7.59	3.36	0.65		1.26	103.00	0	80	12	10	78	9.3	238	-0.62	1.24	0.43	Negative	Negative
9/27/2026	18.0	7.59	3.36	0.69		1.29	118.00	0	82	14	10	76	9.1	232	-0.62	1.39	0.45	Negative	Negative
9/28/2026	18.0	7.57	3.35	0.71	0.70	1.33	106.00	0	80	13	10	80	9.1	227	-0.63	1.29	0.44	Negative	Negative
9/29/2026	17.9	7.56	3.36	0.71		1.34	104.00	0	79	13	9	78	9.3	222	-0.65	1.41	0.42	Negative	Negative
9/30/2026	18.2	7.56	3.36	0.70		1.33	102.00	0	77	13	9	78	9.2	218	-0.66	1.39	0.43	Negative	Negative
Avg	19.8	7.55	3.38	0.70	0.70	1.31	103.50	0	77	12	11	76	9.2	240	-0.65	1.17	0.45	NA	NA
Min	17.9	7.51	3.32	0.65	0.69	1.26	96.60	0	74	11	9	67	8.2	218	-0.73	0.83	0.42	NA	NA
Max	21.6	7.59	3.43	0.71	0.71	1.34	118.00	0	82	15	15	86	11.0	280	-0.55	1.53	0.52	NA	NA

Plant Tap Disinfection Byproduct Monitoring - Results in ppb			
Total Trihalomethanes - TTHM			
Date:	September 15th	August 5th	July 14th
Result:	48	45	59

Turbidity										
	Raw Water		Clarified Water	Membrane Feed Water	Combined Membrane Filtrate					Finished Water
	Avg	Max	Avg	Avg	Avg	Max	# Samples	# > 0.3	% Exceeded	Avg
	NTU									
Date	AIT-1000-1		AIT-5030-1	AIT-1035-3	AIT-4000-1					Calculated
9/1/2026	0.47	0.69	2.56	0.51	0.033	0.034	96	0	0.0	0.029
9/2/2026	0.44	0.50	5.39	0.45	0.033	0.034	96	0	0.0	0.029
9/3/2026	0.41	0.45	8.17	0.42	0.032	0.034	96	0	0.0	0.029
9/4/2026	0.41	0.57	10.23	0.40	0.032	0.034	96	0	0.0	0.029
9/5/2026	0.50	0.66	13.23	0.42	0.032	0.034	96	0	0.0	0.029
9/6/2026	0.57	0.76	16.61	0.48	0.032	0.034	96	0	0.0	0.029
9/7/2026	0.74	0.91	20.37	0.59	0.034	0.034	96	0	0.0	0.029
9/8/2026	0.65	0.77	32.76	0.67	0.034	0.036	96	0	0.0	0.030
9/9/2026	0.83	1.45	65.10	0.73	0.034	0.036	96	0	0.0	0.030
9/10/2026	1.00	4.05	47.59	0.83	0.035	0.036	96	0	0.0	0.030
9/11/2026	0.99	2.45	48.86	0.95	0.035	0.036	96	0	0.0	0.030
9/12/2026	1.00	1.17	42.69	0.89	0.034	0.035	96	0	0.0	0.030
9/13/2026	0.79	1.04	53.50	0.94	0.033	0.035	96	0	0.0	0.030
9/14/2026	0.92	10.01	72.54	0.87	0.033	0.033	96	0	0.0	0.029
9/15/2026	0.75	0.91	68.60	0.83	0.033	0.033	96	0	0.0	0.029
9/16/2026	0.82	1.25	62.52	0.78	0.033	0.033	96	0	0.0	0.029
9/17/2026	1.10	1.46	62.35	0.91	0.031	0.032	96	0	0.0	0.029
9/18/2026	1.05	1.20	26.94	0.91	0.031	0.032	96	0	0.0	0.029
9/19/2026	1.12	1.50	16.79	0.95	0.032	0.033	96	0	0.0	0.029
9/20/2026	0.93	1.25	48.72	1.02	0.032	0.033	96	0	0.0	0.029
9/21/2026	0.71	0.94	38.13	0.84	0.032	0.032	96	0	0.0	0.029
9/22/2026	2.23	8.78	18.25	0.92	0.030	0.032	96	0	0.0	0.028
9/23/2026	6.13	7.71	58.77	2.89	0.031	0.032	96	0	0.0	0.028
9/24/2026	5.84	10.01	84.52	4.12	0.032	0.033	96	0	0.0	0.029
9/25/2026	5.90	8.47	81.53	3.67	0.033	0.034	96	0	0.0	0.030
9/26/2026	3.69	5.02	90.15	3.18	0.034	0.034	96	0	0.0	0.031
9/27/2026	2.35	5.78	80.91	2.92	0.032	0.034	96	0	0.0	0.030
9/28/2026	1.69	1.99	32.42	2.05	0.031	0.033	96	0	0.0	0.029
9/29/2026	1.26	1.89	4.69	1.49	0.031	0.031	96	0	0.0	0.029
9/30/2026	0.80	1.16	8.82	0.96	0.032	0.035	96	0	0.0	0.029
Avg	1.54	2.83	40.79	1.25	0.032	0.034	96	0	0.0	0.029
Min	0.41	0.45	2.56	0.40	0.030	0.031	96	0	0.0	0.028
Max	6.13	10.01	90.15	4.12	0.035	0.036	96	0	0.0	0.031

Note: % Exceeded are 4 hr compliance periods where the average of samples are greater than 0.3 NTU

Membrane LRV/Integrity/Max Turbidity																								
	Membrane 1			Membrane 2			Membrane 3			Membrane 4			Membrane 5			Membrane 6			Membrane 7			Membrane 8		
	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity	LRV	Integrity	Turbidity
	Minimum		Max	Minimum		Max	Minimum		Max	Minimum		Max	Minimum		Max	Minimum		Max	Minimum		Max	Minimum		Max
Date	Daily Value	Pass/Fail	NTU	Daily Value	Pass/Fail	NTU	Daily Value	Pass/Fail	NTU	Daily Value	Pass/Fail	NTU	Daily Value	Pass/Fail	NTU	Daily Value	Pass/Fail	NTU	Daily Value	Pass/Fail	NTU	Daily Value	Pass/Fail	NTU
9/1/2026	5.25	PASS	0.029	5.16	PASS	0.031	5.20	PASS	0.028	5.27	PASS	0.029	5.34	PASS	0.027	4.96	PASS	0.029	5.42	PASS	0.028	5.36	PASS	0.029
9/2/2026	5.22	PASS	0.028	5.16	PASS	0.031	5.17	PASS	0.028	5.23	PASS	0.029	5.34	PASS	0.027	4.94	PASS	0.029	5.43	PASS	0.028	5.36	PASS	0.029
9/3/2026	5.23	PASS	0.029	5.11	PASS	0.031	5.16	PASS	0.028	5.20	PASS	0.029	5.32	PASS	0.027	4.96	PASS	0.029	5.40	PASS	0.028	5.33	PASS	0.029
9/4/2026	5.26	PASS	0.028	5.08	PASS	0.031	5.17	PASS	0.028	5.20	PASS	0.029	5.31	PASS	0.027	5.28	PASS	0.030	5.40	PASS	0.028	5.20	PASS	0.029
9/5/2026	5.24	PASS	0.028	5.07	PASS	0.031	5.16	PASS	0.028	5.19	PASS	0.029	5.27	PASS	0.027	5.28	PASS	0.030	5.45	PASS	0.028	5.22	PASS	0.029
9/6/2026	5.21	PASS	0.029	5.06	PASS	0.031	5.12	PASS	0.028	5.15	PASS	0.029	5.22	PASS	0.027	5.23	PASS	0.029	5.42	PASS	0.028	5.24	PASS	0.029
9/7/2026	5.18	PASS	0.029	5.09	PASS	0.031	5.12	PASS	0.029	5.16	PASS	0.030	5.17	PASS	0.028	5.21	PASS	0.030	5.41	PASS	0.029	5.26	PASS	0.029
9/8/2026	5.14	PASS	0.030	5.02	PASS	0.032	4.96	PASS	0.030	5.12	PASS	0.030	5.15	PASS	0.028	4.81	PASS	0.034	5.29	PASS	0.030	5.15	PASS	0.030
9/9/2026	4.95	PASS	0.030	4.94	PASS	0.032	4.74	PASS	0.030	5.01	PASS	0.030	4.93	PASS	0.029	4.79	PASS	0.032	5.23	PASS	0.030	4.93	PASS	0.030
9/10/2026	4.98	PASS	0.030	4.59	PASS	0.033	4.73	PASS	0.030	4.90	PASS	0.031	4.91	PASS	0.029	4.89	PASS	0.031	5.24	PASS	0.030	4.75	PASS	0.031
9/11/2026	5.00	PASS	0.030	4.60	PASS	0.033	4.80	PASS	0.030	4.94	PASS	0.031	4.94	PASS	0.029	5.07	PASS	0.031	5.23	PASS	0.030	4.81	PASS	0.031
9/12/2026	5.04	PASS	0.030	4.67	PASS	0.032	4.88	PASS	0.030	4.97	PASS	0.030	5.14	PASS	0.029	5.08	PASS	0.031	5.25	PASS	0.030	4.80	PASS	0.030
9/13/2026	4.92	PASS	0.030	4.93	PASS	0.033	4.86	PASS	0.030	5.07	PASS	0.030	4.97	PASS	0.028	4.86	PASS	0.031	5.18	PASS	0.030	4.73	PASS	0.030
9/14/2026	4.92	PASS	0.029	4.79	PASS	0.031	4.71	PASS	0.029	4.96	PASS	0.031	4.87	PASS	0.028	4.66	PASS	0.030	5.14	PASS	0.029	4.73	PASS	0.030
9/15/2026	4.96	PASS	0.029	4.70	PASS	0.032	4.72	PASS	0.029	4.93	PASS	0.031	4.81	PASS	0.028	4.65	PASS	0.030	5.04	PASS	0.029	4.75	PASS	0.030
9/16/2026	4.98	PASS	0.029	4.77	PASS	0.032	4.74	PASS	0.030	5.06	PASS	0.031	4.78	PASS	0.028	4.87	PASS	0.030	5.05	PASS	0.029	4.68	PASS	0.030
9/17/2026	4.99	PASS	0.029	4.89	PASS	0.032	4.72	PASS	0.029	4.96	PASS	0.032	4.84	PASS	0.028	4.90	PASS	0.030	5.12	PASS	0.029	4.64	PASS	0.029
9/18/2026	5.10	PASS	0.029	5.13	PASS	0.032	4.93	PASS	0.029	5.07	PASS	0.032	4.88	PASS	0.028	5.09	PASS	0.030	5.23	PASS	0.029	4.82	PASS	0.029
9/19/2026	5.08	PASS	0.029	5.02	PASS	0.032	4.91	PASS	0.029	5.06	PASS	0.032	4.96	PASS	0.028	4.73	PASS	0.030	5.24	PASS	0.030	4.90	PASS	0.029
9/20/2026	4.90	PASS	0.030	4.94	PASS	0.032	4.74	PASS	0.029	5.09	PASS	0.032	4.89	PASS	0.028	4.68	PASS	0.030	5.20	PASS	0.029	4.77	PASS	0.030
9/21/2026	4.93	PASS	0.029	4.95	PASS	0.032	4.72	PASS	0.029	5.10	PASS	0.032	4.90	PASS	0.027	4.66	PASS	0.030	5.24	PASS	0.029	4.77	PASS	0.029
9/22/2026	5.04	PASS	0.028	5.02	PASS	0.031	4.90	PASS	0.028	5.16	PASS	0.031	4.98	PASS	0.027	4.91	PASS	0.029	5.24	PASS	0.028	4.98	PASS	0.029
9/23/2026	5.09	PASS	0.029	5.12	PASS	0.032	4.89	PASS	0.029	5.15	PASS	0.031	5.01	PASS	0.028	5.14	PASS	0.030	5.24	PASS	0.029	5.05	PASS	0.029
9/24/2026	5.19	PASS	0.030	5.08	PASS	0.032	4.83	PASS	0.030	5.19	PASS	0.033	4.81	PASS	0.029	4.82	PASS	0.030	5.39	PASS	0.030	5.03	PASS	0.030
9/25/2026	5.16	PASS	0.032	5.08	PASS	0.035	4.87	PASS	0.032	5.47	PASS	0.036	4.80	PASS	0.031	4.80	PASS	0.033	5.38	PASS	0.032	5.01	PASS	0.032
9/26/2026	5.06	PASS	0.032	4.92	PASS	0.035	4.88	PASS	0.032	5.42	PASS	0.035	5.14	PASS	0.031	4.84	PASS	0.033	5.50	PASS	0.032	5.07	PASS	0.032
9/27/2026	5.07	PASS	0.031	4.92	PASS	0.034	4.91	PASS	0.031	5.37	PASS	0.034	5.12	PASS	0.030	5.11	PASS	0.032	5.41	PASS	0.031	5.06	PASS	0.032
9/28/2026	5.21	PASS	0.030	4.77	PASS	0.033	4.92	PASS	0.030	5.38	PASS	0.033	5.14	PASS	0.029	5.26	PASS	0.030	5.40	PASS	0.030	5.03	PASS	0.031
9/29/2026	5.24	PASS	0.029	4.79	PASS	0.031	4.95	PASS	0.029	5.45	PASS	0.032	5.15	PASS	0.028	4.94	PASS	0.029	5.38	PASS	0.029	5.08	PASS	0.029
9/30/2026	5.29	PASS	0.029	5.05	PASS	0.032	4.98	PASS	0.029	5.49	PASS	0.031	5.17	PASS	0.028	4.99	PASS	0.030	5.40	PASS	0.029	5.11	PASS	0.029
Avg	5.09		0.029	4.95		0.032	4.91		0.029	5.16		0.031	5.04		0.028	4.95		0.030	5.30		0.029	4.99		0.030
Min	4.90		0.028	4.59		0.031	4.71		0.028	4.90		0.029	4.78		0.027	4.65		0.029	5.04		0.028	4.64		0.029
Max	5.29		0.032	5.16		0.035	5.20		0.032	5.49		0.036	5.34		0.031	5.28		0.034	5.50		0.032	5.36		0.032

Note: As calculated by the manufacturer, the Upper Control Limit (UCL) for the installed membrane filtration system is 3.32 psi/min.
Per the manufacturer's UCL calculation: Q = 1,848 gpm, ALCR = 44.6, P atm = 14.4 psi, LRC = 3, V sys = 356.9 gallons, and VCF = 1.

Operational Guidelines: We have established the following parameter values as control limits to trigger skids to be taken out of service and evaluated.

Min LRV: A value of 3.3.

Max NTU: A turbidity reading of 0.15 NTU or greater.

Flow or Q: While not shown here, a skid will be evaluated if it cannot sustain a flow above 1,000 GPM

Max Air Hold Test Result: While not shown on this page, an AHT result of 0.84 PSI/Min or greater.

In Service Dates For Modules			
Train 1		Train 2	
Skid 1	8/2024	12/2023	Skid 2
Skid 3	11/2023	7/2025	Skid 4
Skid 5	2/2023	10/2024	Skid 6
Skid 7	8/2025	1/2023	Skid 8

Treatment Chemical Dosages											
	Treated Water	Sodium Hypochlorite					Phosphoric Acid		Hydroflourosilicic Acid		
		Raw Water	Membrane Feed Water	Dose pre-FW Tanks	Treated Water	Post FW Tanks	Dose pre-FW Tanks	Post FW Tanks	Raw Water	Dose pre-FW Tanks	Post FW Tanks
	Volume	Free Cl_2					PO4		F^-		
	MG	mg/L					mg/L		mg/L		
Date	FIT-4000-1	AIT-1035-2	AIT-1035-4	Added	AIT-4030-1	AIT-4050-1	Added	AIT-4040-5	Lab - Mem Feed	Added	Lab
9/1/2026	8.4	0.29	0.15	1.35	1.37	1.32	3.15	3.32	0.09	0.57	0.71
9/2/2026	8.7	0.32	0.18	1.37	1.37	1.32	3.15	3.43	0.09	0.56	0.69
9/3/2026	8.4	0.31	0.18	1.34	1.37	1.32	3.15	3.43	0.09	0.56	0.69
9/4/2026	7.5	0.29	0.17	1.34	1.35	1.30	3.15	3.42	0.09	0.56	0.69
9/5/2026	7.2	0.28	0.15	1.38	1.37	1.29	3.15	3.40	0.09	0.56	0.69
9/6/2026	7.4	0.34	0.15	1.41	1.39	1.30	3.15	3.40	0.09	0.56	0.69
9/7/2026	8.4	0.15	0.10	1.48	1.35	1.31	3.15	3.41	0.09	0.56	0.69
9/8/2026	8.1	0.13	0.06	1.55	1.35	1.28	3.15	3.40	0.09	0.56	0.69
9/9/2026	8.5	0.10	0.04	1.60	1.40	1.30	3.15	3.40	0.09	0.56	0.70
9/10/2026	8.8	0.06	0.04	1.60	1.39	1.29	3.15	3.40	0.09	0.55	0.71
9/11/2026	9.1	0.06	0.03	1.64	1.40	1.28	3.15	3.39	0.09	0.55	0.70
9/12/2026	8.2	0.11	0.04	1.64	1.42	1.29	3.15	3.38	0.09	0.55	0.71
9/13/2026	7.5	0.15	0.04	1.64	1.41	1.28	3.15	3.38	0.09	0.55	0.69
9/14/2026	8.6	0.18	0.06	1.64	1.41	1.31	3.15	3.39	0.09	0.55	0.68
9/15/2026	7.9	0.21	0.04	1.64	1.39	1.32	3.15	3.37	0.09	0.55	0.69
9/16/2026	8.1	0.23	0.04	1.64	1.39	1.31	3.15	3.37	0.09	0.55	0.69
9/17/2026	7.7	0.34	0.09	1.60	1.39	1.33	3.15	3.36	0.09	0.55	0.70
9/18/2026	8.1	0.25	0.08	1.60	1.37	1.32	3.15	3.35	0.09	0.55	0.71
9/19/2026	7.2	0.31	0.09	1.60	1.38	1.29	3.15	3.36	0.09	0.55	0.71
9/20/2026	7.0	0.35	0.08	1.32	1.42	1.31	3.15	3.36	0.09	0.55	0.71
9/21/2026	7.8	0.42	0.10	1.20	1.39	1.34	3.15	3.37	0.09	0.54	0.70
9/22/2026	7.8	0.49	0.19	1.08	1.40	1.34	3.15	3.36	0.09	0.54	0.70
9/23/2026	8.0	0.16	0.08	1.24	1.36	1.30	3.15	3.36	0.09	0.54	0.70
9/24/2026	7.3	0.10	0.04	1.26	1.39	1.32	3.15	3.36	0.09	0.54	0.68
9/25/2026	7.5	0.06	0.03	1.33	1.39	1.29	3.15	3.36	0.10	0.54	0.70
9/26/2026	7.1	0.15	0.03	1.30	1.42	1.26	3.15	3.36	0.08	0.54	0.65
9/27/2026	7.5	0.28	0.05	1.30	1.43	1.29	3.15	3.36	0.10	0.55	0.69
9/28/2026	8.6	0.35	0.07	1.24	1.41	1.33	3.15	3.35	0.09	0.55	0.71
9/29/2026	8.1	0.44	0.12	1.17	1.39	1.34	3.15	3.36	0.09	0.55	0.71
9/30/2026	7.9	0.52	0.22	1.13	1.37	1.33	3.15	3.36	0.09	0.55	0.70
Avg	7.9	0.25	0.09	1.42	1.39	1.31	3.15	3.38	0.09	0.55	0.70
Min	7.0	0.06	0.03	1.08	1.35	1.26	3.15	3.32	0.08	0.54	0.65
Max	9.1	0.52	0.22	1.64	1.43	1.34	3.15	3.43	0.10	0.57	0.71

Disinfection CT														
	Pipeline CT				FW Tank CT						Compliance			
	Whitestone	Travel Time	Residual	CT	FW Tank 1	FW Tank 2	Plant	Contact Time	Free Cl_2	CT	Total CT	Temp	CT	CT
	Flow	Min	RW	Achieved	Min Level	Min Level	Flow	Min	Min	Achieved	Achieved	Avg	Required	Met
	MGD	Minutes	mg/L	mg-min/L	ft	ft	MGD	Minutes	mg/L	mg-min/L	mg-min/L	°C	mg-min/L	Y/N
Date	Entry	Calculated	AIT-1035-2	Calculated	LIT-4005-1	LIT-4005-2	Calculated	Calculated	Calculated	Calculated	Calculated	AIT-4040-1	Calculated	Calculated
9/1/2026	53.7	2,328	0.29	678	28.2	22.9	7.8	451	1.29	291	969	21.1	2.00	Y
9/2/2026	54.8	2,282	0.32	741	28.4	23.5	8.0	445	1.27	282	1024	21.0	2.00	Y
9/3/2026	54.8	2,283	0.31	711	28.4	24.4	7.7	468	1.26	294	1005	20.9	2.00	Y
9/4/2026	52.1	2,401	0.29	687	28.2	23.2	6.9	511	1.18	301	988	20.8	2.00	Y
9/5/2026	61.5	2,036	0.28	574	28.2	24.7	6.6	550	1.24	341	914	20.8	2.00	Y
9/6/2026	62.6	1,999	0.34	674	28.2	23.5	6.6	536	1.26	338	1012	21.0	2.00	Y
9/7/2026	63.1	1,982	0.15	295	28.4	23.6	7.7	465	1.29	300	595	21.2	2.00	Y
9/8/2026	51.0	2,451	0.13	320	28.2	22.3	7.5	460	1.21	279	599	21.4	2.00	Y
9/9/2026	52.0	2,405	0.10	250	28.3	23.8	7.7	464	1.22	282	532	21.6	2.00	Y
9/10/2026	52.7	2,373	0.06	147	28.4	21.7	8.3	411	1.25	257	404	21.5	2.00	Y
9/11/2026	55.3	2,261	0.06	140	28.4	23.2	8.3	427	1.26	269	409	21.4	2.00	Y
9/12/2026	65.8	1,900	0.11	202	28.4	23.7	7.4	483	1.13	274	476	21.2	2.00	Y
9/13/2026	67.1	1,865	0.15	287	28.2	22.4	7.2	482	1.23	297	583	20.9	2.00	Y
9/14/2026	61.8	2,025	0.18	367	28.3	21.7	7.7	443	1.28	285	651	20.1	2.00	Y
9/15/2026	54.2	2,307	0.21	473	28.2	23.6	7.2	492	1.25	308	782	19.7	4.00	Y
9/16/2026	47.7	2,622	0.23	591	28.3	22.0	7.4	464	1.27	294	885	19.7	4.00	Y
9/17/2026	49.7	2,515	0.34	850	28.4	24.2	7.2	503	1.27	318	1168	19.2	4.00	Y
9/18/2026	51.0	2,453	0.25	614	28.2	21.9	7.4	463	1.28	296	910	18.7	4.00	Y
9/19/2026	57.5	2,177	0.31	682	28.2	22.9	6.6	530	1.24	328	1010	18.8	4.00	Y
9/20/2026	58.3	2,144	0.35	757	28.2	22.8	6.4	543	1.23	335	1092	19.0	4.00	Y
9/21/2026	50.0	2,503	0.42	1040	28.4	24.9	7.1	513	1.31	335	1376	18.9	4.00	Y
9/22/2026	50.4	2,482	0.49	1218	28.2	23.4	7.1	499	1.29	322	1540	18.8	4.00	Y
9/23/2026	50.6	2,474	0.16	401	28.4	23.6	7.3	489	1.28	313	714	18.8	4.00	Y
9/24/2026	49.3	2,537	0.10	244	28.2	22.6	6.7	521	1.29	336	580	18.6	4.00	Y
9/25/2026	47.6	2,628	0.06	150	28.2	21.6	6.9	495	1.26	312	462	18.4	4.00	Y
9/26/2026	57.4	2,181	0.15	322	28.2	21.4	6.4	529	1.24	328	651	18.2	4.00	Y
9/27/2026	58.3	2,145	0.28	595	28.2	21.2	7.1	480	1.26	303	897	18.0	4.00	Y
9/28/2026	57.8	2,165	0.35	751	28.2	22.6	7.7	452	1.31	296	1047	18.0	4.00	Y
9/29/2026	53.4	2,344	0.44	1042	28.2	24.2	7.4	486	1.29	314	1356	17.9	4.00	Y
9/30/2026	49.0	2,555	0.52	1332	28.2	25.0	7.3	500	1.25	312	1643	18.2	4.00	Y
Avg	55.0	2,294	0.25	571	28.3	23.1	7.3	485	1.26	305	876	19.8	3.07	NA
Min	47.6	1,865	0.06	140	28.2	21.2	6.4	411	1.13	257	404	17.9	2.00	NA
Max	67.1	2,628	0.52	1332	28.4	25.0	8.3	550	1.31	341	1643	21.6	4.00	NA

Notes:

Pipeline volume factor in SMMWSC to RW tank: 125,090 MG-min/day

Distribution System Monitoring

Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl_2)

WSSN:	0072	0390				0400			0470							0485					0517	0518		2180
	Akron	Bangor Twp.				Bangor Monitor Dist.			Bay City							Bay County					Beaver Rd	Beaver Twp		Essexville
Date	1	3	4	5	6	7	9	10	11	12	13	14	15	16	17	18	19	20	23	24	26	29	30	32
9/1/2026	0.04	0.33	0.21	0.89	0.26											0.75	0.79	0.86	0.78	0.38		0.35		1.09
9/2/2026																								
9/3/2026						0.81	0.86		0.61	0.24	0.42	0.64	0.34	0.94										
9/4/2026																								
9/5/2026																								
9/6/2026																								
9/7/2026																								1.09
9/8/2026				0.38	0.98											0.86	0.62	0.73	0.76	0.48			0.38	
9/9/2026									0.67	0.15	0.37	0.64	0.35	0.95										
9/10/2026								0.99													0.77			
9/11/2026																								
9/12/2026																								
9/13/2026																								
9/14/2026																								
9/15/2026		0.33	0.33	0.37	1.00				0.68	0.25	0.23	0.66	0.34	0.95										
9/16/2026																								1.05
9/17/2026									0.71	0.37	0.39	0.68	0.33	0.98										
9/18/2026																								
9/19/2026																								
9/20/2026																								
9/21/2026																								0.98
9/22/2026																								
9/23/2026									0.64	0.27	0.46	0.75	0.29	1.03										
9/24/2026																								
9/25/2026																								
9/26/2026																								
9/27/2026																								
9/28/2026																								0.98
9/29/2026									0.73	0.31	0.40	0.62	0.30	1.03										
9/30/2026																								
Average	0.04	0.51				0.89			0.55							0.70					0.77	0.37		1.04
Min	0.04	0.21				0.81			0.15							0.38					0.77	0.35		0.98
Max	0.04	1.00				0.99			1.03							0.86					0.77	0.38		1.09

MONITORING STATION ADDRESSES

1. Sample station at corner of 5758 M-25 & R
3. Bangor Fire Station, 3921 Wheeler
4. BCDWS Admin. Bldg. 3933 Patterson Rd.
5. 7-11, 3543 S. Old Kawkawlin Rd.
6. Admiral Petroleum, 314 S Euclid Ave.
7. Sequin Lumber, 3881 Euclid Ave
9. Top Gun Liquor, 2981 Midland Rd
10. Little Caesars, 3475 E North Union Rd
11. Number 1 Fire Station, 1401 Center Ave
12. Number 2 Fire Station, 1000 Fremont Ave
13. Jack's Fruit Market, 1000 Salzburg Ave
14. Number 4 Fire Station, 212 S. Dean St
15. Number 5 Fire Station, 1209 Smith St
16. Bay City Hall, 301 Washington Ave
17. Skipper Buds Marina, 1809 S Water St
18. Bay Valley Animal Hospital 6015 WS Saginaw Rd
19. Dore's M-84 Party Store, 6183 WS Saginaw Rd
20. Pump Station #13, 6000 WS Saginaw Rd
23. Rail Trail Pump Station, 366 N. Tuscola Rd.
24. Little Learners Daycare, 1694 Cass Ave.
26. Wieland Contracting, 2443 S Mackinaw Rd
29. Sample Station, 2515 S. 11 Mile Rd
30. Sample Station, 340 W. Beaver Rd
32. Essexville City Hall, 1107 Woodside Ave

Comments: Bay City Sample Site #17 Skipper Buds Marina was replaced with 904 Lafayette, a new BacT Sample Plan was submitted to EGLE

Shading Designation Legend	
TC- / EC-	TC+
HPC	EC+

Distribution System Monitoring

Chlorine Residual at Bacteriological Monitoring Stations (mg/L Free Cl_2)

WSSN:	2465		2960				3565			3570		3910		4280		4440			5330		5335		5540	7125			7134
	Fraser Twp.		Hampton Twp.				Kawkawlin Twp.			Kawkawlin Met.		Linwood, LMWD		Merritt Twp.		Monitor Twp.			City Pinconning		Pinconning Twp.		Portsmouth	Williams Twp.			Wisner
Date	34	35	36	37	38	39	40	41	42	43	45	73	74	46	48	49	52	55	58	59	61	63	65	68	69	70	72
9/1/2026														0.34									0.56	0.33	0.50	0.30	0.24
9/2/2026																											
9/3/2026		0.89	0.70	0.36	0.20	0.39	1.22	1.02		0.70		0.72				0.79	0.72	0.69	0.48		0.93						
9/4/2026																											
9/5/2026																											
9/6/2026																											
9/7/2026																											
9/8/2026														0.46										0.58	0.66	0.55	
9/9/2026																											
9/10/2026									0.81	0.56						0.97	0.67	0.59	0.64			0.69					
9/11/2026																											
9/12/2026																											
9/13/2026																											
9/14/2026				0.59	0.23	0.39																					
9/15/2026		0.72																									
9/16/2026																											
9/17/2026																											
9/18/2026																											
9/19/2026																											
9/20/2026																											
9/21/2026																											
9/22/2026				0.23	0.32	0.44																					
9/23/2026																											
9/24/2026																											
9/25/2026																											
9/26/2026																											
9/27/2026																											
9/28/2026																											
9/29/2026																											
9/30/2026																											
Average	0.81		0.39				1.02			0.63		0.72		0.40		0.74			0.56		0.81		0.56	0.49			0.24
Min	0.72		0.20				0.81			0.56		0.72		0.34		0.59			0.48		0.69		0.56	0.30			0.24
Max	0.89		0.70				1.22			0.70		0.72		0.46		0.97			0.64		0.93		0.56	0.66			0.24

MONITORING STATION ADDRESSES

34. Fraser Elevated Tank, 2949 1/2 N. Huron Rd
35. Lloyd's Cabinet, 1947 N Huron Rd
36. Shirts Mugs & More, 2728 Center Ave
37. Hampton DPW, 950 Wagner Rd.
38. Bay County Golf Course, 584 W Hampton Rd.
39. Sewer Lift Station, 902 Nebobish Rd.
40. Bay Co. Road Commisison, 2600 E Beaver Rd
41. Parish Rd. Elevated Tank, 1770 E. Parish Rd
42. Linwood Tile, 205 S Huron Rd
43. Speedway, 106 S. Huron Rd.
45. Kawkawlin Restaurant, 103 S Huron Rd
46. John's Bar, 1476 S Tuscola Rd
48. Tool Shed Bar, 12 W Munger Rd
49. Wilder Rd Party Store, 2951 E Wilder Rd
52. Monitor Twp. Elevated Tank, 1611 E. Midland Rd
55. Auburn Fertilizer, 4640 S 7 Mile Rd
58. Pinconning City Hall, 208 S Manitou St
59. Marathon Gas Station, 511 S Mabel St
61. Pinconning Meter Pit, 3005 N Huron Rd
63. Master Meter Pit, 2865 Pinconning Rd
65. Ike's Welding, 50 N Finn Rd
68. Williams Township Hall, 1080 W Midland Rd
69. Pump Station, 490 W. Salzburg & 9 Mile Rd
70. 11 Mile Elevated Tank, 5003 S. 11 Mile Rd
72. Lindy's Sales, 9051 M-25
73. Larry Chambers, 407 W. Clara Street
74. Linwood Party and Sporting Goods, 211 W. Center St.

Shading Designation Legend	
TC- / EC-	TC+ / EC-
HPC	EC+

Distribution System Bacteriological

Water Supplier Bacteriological Analysis Report

MICHIGAN DEPARTMENT OF PUBLIC HEALTH
Bureau of Environmental Health
Water Supplier Bacteriological Analysis Report

September, 2026

Name of Water Supply:
Bay Area Water System - WSSN 0465

DISTRIBUTION SYSTEM SAMPLES

COUNTY	COMMUNITY	WSSN	CHLORINE MONITORING			BACTERILOGICAL MONITORING					
			AVERAGE FREE CL_2 RESIDUAL	SAMPLES WITH NO DECTECTABLE* FREE CL_2 RESIDUAL	PERCENT OF SAMPLES WITH NO DECTECTABLE* FREE CL_2 RESIDUAL	NUMBER OF ROUTINE SAMPLES REQUIRED	NUMBER OF SAMPLES COLLECTED	NUMBER OF POSITIVE SAMPLES	REPEAT SAMPLES REQUIRED	NUMBER OF REPEAT SAMPLES GATHERED	REPEAT SAMPLING COMPLETE
Tuscola	Akron	0072	0.04	0	0	1	1	0			
BAY	Bangor Township	0390	0.51	0	0	10	10	0			
BAY	Bangor-Monitor Dist.	0400	0.89	0	0	3	3	0			
BAY	Bay City	0470	0.55	0	0	30	36	0			
BAY	Bay County (Frankl./Monitor/Portsm.)	0485	0.70	0	0	9	10	0			
BAY	Beaver Road Area	0517	0.77	0	0	1	1	0			
BAY	Beaver Township	0518	0.37	0	0	2	2	0			
BAY	Essexville	2180	1.04	0	0	4	5	0			
BAY	Fraser Township	2465	0.81	0	0	2	2	0			
BAY	Hampton Township	2960	0.39	0	0	10	10	0			
BAY	Kawkawlin Township	3565	1.02	0	0	3	3	0			
BAY	Kawkawlin Metro Dist.	3570	0.63	0	0	2	2	0			
BAY	Linwood Metro Water District	3910	0.72	0	0	1	1	0			
BAY	Merritt Township	4280	0.40	0	0	2	2	0			
BAY	Monitor Township	4440	0.74	0	0	6	6	0			
BAY	City of Pinconning	5330	0.56	0	0	2	2	0			
BAY	Pinconning Township	5335	0.81	0	0	2	2	0			
BAY	Portsmouth Township	5540	0.56	0	0	1	1	0			
BAY	Williams Township	7125	0.49	0	0	6	6	0			
Tuscola	Wisner	7134	0.24	0	0	1	1	0			

Total Distribution - Free Chlorine Samples

Required Number of Routine Samples:	98	
Total Number of Routine Samples Gathered:	106	
Free Chlorine Analysis:		
Minimum Free Chlorine Residual:	0.04	mg/L
Average Free Chlorine Residual:	0.60	mg/L
Median Free Chlorine Residual:	0.62	mg/L
Maximum Free Chlorine Residual:	1.22	mg/L
Range of Free Chlorine Residual:	1.18	mg/L
Water Plant's Free Chlorine Residual at POE to Distribution:		
Minimum Free Chlorine Residual:	1.26	mg/L
Average Free Chlorine Residual:	1.31	mg/L
Maximum Free Chlorine Residual:	1.34	mg/L

DETECTABLE*: The detectable level of free chlorine is determined by having either a free chlorine residual greater than or equal to 0.02 mg/L at the time of sample collection or by HPC results less than or equal to 500 colony forming units (CFU) per mL.

Repeat Bacteriological Sampling Details

If repeat samples were required, this space will be filled out to document those details.